

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204748  
Address: 1516 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Wednesday, December 08, 2021

Corrective Action Required:

1	Misc	TCO UNTIL 02/03/22 -provide 6" of clearance between siding and grade -address meter well full of dirt, provide minimum 12" clearance beneath meter assembly -sidewalk inspection still pending
---	------	---

Comments: