

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Curb Construction	Adam Nacke	Passed	Wednesday, December 08, 2021

Corrective Action Required:

1	Miscellaneous Correction	11-5-21 AN park ridge 7th and 8th . Seal o matic has been doing grading on the roadway getting ready for asphalt and damaged the curbs. The ones with x's need to be taken out and replaced and the one's with just dots need patched. There are AROUND 50 curb sections at 12ft each == 600ft that need replacing.. attached pics (damaged curb 1- 10)
---	-----------------------------	--

Informational:

2	Miscellaneous Correction	11-18-21 AN crew started saw cutting damaged the curbs for removal 11-22-21 AN all damaged curbs have now been removed.
---	-----------------------------	--

Informational:

3	Misc	12-8-21 AN it appears that all the damaged curbs have been replaced .
---	------	---

Comments: