

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214329
Address: 940 NW PRYOR RD, Unit:J, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Wednesday, December 08, 2021

Corrective Action Required:	
1	Miscellaneous Correction
	PROVIDE BOCA PLATES RESTROOM & DOG WASH STATIONS PROVIDE PLUMBING PROTECTION PLATES RESTROOM & DOG WASH STATIONS FIRE CAULK UPWARD FLOOR PENETRATIONS

Comments: