

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210592
Address: 134 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Wednesday, December 08, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide sod & splash blocks Seal top exterior light fixtures Provide gutters & downspouts Land conductors in a box or listed fixture right of cooktop Install ceiling fan or cover plate NW bedroom Complete backsplash & cover plates wet bar basement Seal top AC disconnect Land sewer tracer wire in a box at grade
---	--------------------------	--

Comments: