

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Ronald Paynter	Partial	Thursday, December 09, 2021

Informational:
1 Misc Collected second Bac T samples from O'Brien cul de sac, Patch Ct and O'Brien Rd. Chlorine was absent from the Killarney sample, so we took first sample also. Delivered samples to Keystone Laboratories for testing. RP 12-8-21

Comments: