

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214712
Address: 792 NE ALGONQUIN ST, LEES SUMMIT, MO 64064794 NE ALGONQUIN ST, LEES SUMMIT, MO
64064790 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Thursday, December 09, 2021

Corrective Action Required:
1 Misc -PROVIDE CONTINUOUS GRAVEL SUPPORT

Comments: