

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Michael Harkins	Failed	Thursday, December 09, 2021

Corrective Action Required:

1	Miscellaneous Correction	- LIGHT POLE BASE PIERS SHALL BE 5'-0" BELOW GRADE PER PLAN -
---	--------------------------	---

Comments: