

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211033  
Address: 4421 SW TANZANITE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome: | Date:                       |
|---|------------------|----------|-----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Failed   | Thursday, December 09, 2021 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -final grade and sod<br>-check water meter and siding to grade spacing at time of final grade and sod<br>-splash blocks and sump pump discharge to extend 36" from foundation<br>-seal top of A/c disconnect<br>-Provide guard rail at front stoop where more than 30", 36" out<br>-attic access cover for 2nd story attic access<br>-security screws at basement back door |
|---|------|---|

**Comments:**