

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Thursday, December 09, 2021

Informational:	
1	THIRD FLOOR
	-AREAS APPROVED-
	BUILDING C COMPLETE
	BUILDING B COMPLETE
	BUILDING A COMPLETE EXCEPT ELEVATOR

Informational:	
2	SECOND FLOOR
	-AREAS APPROVED-
	BUILDING C: COMPLETE
	BUILDING B: COMPLETE
	BUILDING A: COMPLETE EXCEPT AT ELEVATOR

Informational:

3 FIRST FLOOR

-AREAS APPROVED-

BUILDING C
COMPLETE

BUILDING B
COMPLETE

BUILDING A
COMPLETE

****MCAL BUILDING***
COMPLETE EXCEPT AS NOTED:

-166-COMPLETE SECOND LAYER ABOVE CEILING
-165- RC OK
-164- COMPLETE RATED LAYER AT DISHWASHER HOOD, RC OK

Corrective Action Required:

4 Miscellaneous
Correction

SEAL PENETRATIONS AND FIRE TAPE AT SECOND LAYER OF SEPARATION WALL
AT IL/AL-ROOM 166

Corrective Action Required:

5 ELEVATOR 1

-FUR OUT WALLS OK
-RC AND SCREW PATTERN OK

-SEAL BLOCK AT DOOR SIDE CEILING LEVEL, FIRE TAPE AND SEAL GAPS

Comments: