

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20202008  
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Ronald Paynter	Partial	Thursday, December 09, 2021

Informational:		
1	Misc	Chlorinated water lines for O'Brien, Patch and Killarney. Will let them set over the weekend. RP 12-3-21
Informational:		
2	Misc	Dechlorinated the water line. RP 12-6-21
Informational:		
3	Misc	Pulled Bac T samples from Killarney, Patch Ct, O'Brien cul de sac and O'Brien Rd. Delivered samples to Keystone Laboratories for testing. RP 12-7-21
Informational:		
4	Misc	O'Brien cul de sac, Patch Ct, and O'Brien Rd passed their first Bac T test. RP 12-9-21

**Comments:**