

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211543
Address: 1905 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Friday, December 10, 2021

Corrective Action Required:

1	Misc	-Complete electrical to fireplace **plug connection must be accessible at final
		-At front bathroom at foyer, Fb space at tub from roof and Fb at trap
		**OK TO ROCK

Comments: