

Letter of Transmittal 4

Client: Hy-Vee Construction
Project: Hy-Vee – Lee's Summit #2 Remodel

Project No: B2100276

Date: August 19, 2021

Braun Intertec Corporation
11529 West 79th Street, Building 21
Lenexa, KS 66214

To: Jack Meyer
Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Phone: (515) 419-5669

Email:

Re: Reports and Test Results

Documents Sent	Comments
Daily Reports	July 27, 2021 – August 13, 2021

Copy List

Contact Information:

Sent By: Carrie Keeling

Email: CKeeling@braunintertec.com

Phone: _____

Special Inspection Daily Report

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:

Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:

B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081

Activity Date: 07/27/2021

Technician: Arndt, Chad

City of: Lee's Summit, MO

Braun Intertec PM: Tyler Fadler

Report Number: 12

Weather: Sunny 97

Coverage	Frequency	Notes
Steel Construction	Periodic	

Architect/engineer authorized changes to approved plans?: **No**

Work Completed Description:

Arrived on site and met with Thomas Remus of Hy Vee Construction who provided the approved contract documents for joist reinforcements under rooftop unit installations below roof decking.

Web reinforcements in the last 7 webs next to the outer wall at grid locations B to C from 5 to 6 were inspected on both joists accordingly above the Starbucks location roof. Fillet welds were found to be acceptable according to size, length, and profile.

Tests Performed:

Visual of welds

Outstanding discrepancies on this project?: No

Report discussed with and sent to contractor?: No

Attachments

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:
Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:
B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081



Jul 27, 2021 2:17:02 PM
310 Southwest Ward Road
Lee's Summit
Jackson County
Missouri

Top connections

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:
Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:
B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081



End

To the best of our knowledge, work inspected was done in accordance with the approved plans, specifications and applicable workmanship provisions of the current IBC, except as noted above.

Special Inspection Daily Report

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:

Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:

B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081

Activity Date: 08/09/2021

Technician: Arndt, Chad

City of: Lee's Summit

Braun Intertec PM: Tyler Fadler

Report Number: 13

Weather: Sunny 96

Coverage	Frequency	Notes
Special Cases	Periodic	Drill and Epoxy
Steel Construction	Periodic	

Architect/engineer authorized changes to approved plans?: **No**

Work Completed Description:

Arrived on site and met with John with Hy Vee Construction who provided the approved contract documents for Drill and Epoxy installation at Grid Line k from 9 to 10 and welding along line 10 from D to G.

Drill / Epoxy:

Installation of the drilled and epoxied rebars was observed at Grid Line K from 9 to 10 at the new door jam installations and the 6 x 4 angle installation at lintel. Installation was observed with respect to hole size, depth, and cleanliness, anchor and dowel size and spacing and type of epoxy used.

Welding:

Welding was inspected along gridline 10 from D to G with the angle installation and beam support below roof decking. Welds were found to be acceptable to AWS D1.1 standards according to size, length, and profile.

Tests Performed:

Visual of Epoxy rebar installation and welding

Outstanding discrepancies on this project?: No

Report discussed with and sent to contractor?: No

Attachments

Special Inspection Daily Report

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:
Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:
B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081



Welding length and pitch acceptable

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:
Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:
B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081



Aug 9, 2021 12:55:33 PM
200 Southwest McClendon Drive
Lee's Summit
Jackson County
Missouri

Structural slab dowels at door wall

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:

Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:

B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081



Lateral anchors in lintel angle above door

To the best of our knowledge, work inspected was done in accordance with the approved plans, specifications and applicable workmanship provisions of the current IBC, except as noted above.

Special Inspection Daily Report

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:
Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:
B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081

Activity Date: 08/11/2021
Technician: Johnson, David

City of: Lees Summitt MO
Braun Intertec PM: Tyler Fadler

Report Number: 14
Weather: Partly cloudy 92

Coverage	Frequency	Notes
Masonry Construction	Periodic	

Architect/engineer authorized changes to approved plans?: **No**

Work Completed Description:

BIC was on-site for observation of grout placement for the isles on line doorways on the northwest corner of the existing building. The grout was placed 0' to 4'. The grout and reinforcing steel were placed in accordance with plans and specifications.

Tests Performed:
Observation

Outstanding discrepancies on this project?: No

Report discussed with and sent to contractor?: No

To the best of our knowledge, work inspected was done in accordance with the approved plans, specifications and applicable workmanship provisions of the current IBC, except as noted above.



Special Inspection Daily Report

11529 W. 79th St, Building 21
Lenexa, KS 66214
Phone: 913-962-0909

Client:
Hy-Vee Construction
5605 N.E. 22nd Street
Des Moines, IA 50313

Project:
B2100276
Hy-Vee - Lee's Summit #2 Remodel
310 SW Ward Rd
Lees Summit, MO 64081

Activity Date: 08/13/2021
Technician: Johnson, David

City of: Lees Summitt MO
Braun Intertec PM: Tyler Fadler

Report Number: 15
Weather: Cloudy 72

Coverage	Frequency	Notes
Masonry Construction	Continuous	

Architect/engineer authorized changes to approved plans?: **No**

Work Completed Description:

BIC was on-site for observation of grout placement for the isles online pickup doorways on the northwest corner of the existing building. The grout was placed from 4' to 8' up to the new steel lenti. The grout, reinforcing steel, anchor bolts, and steel lentils were placed in accordance with plans and specifications. The grout was consolidated by the vibratory method.

Tests Performed:

Obervation

Outstanding discrepancies on this project?: No

Report discussed with and sent to contractor?: No

To the best of our knowledge, work inspected was done in accordance with the approved plans, specifications and applicable workmanship provisions of the current IBC, except as noted above.

