

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211430
Address: 134 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Not Ready	Friday, December 10, 2021

Corrective Action Required:

1	Misc	- 12/8/21 - INSPECTION DENIED, ADDRESS EROSION CONTROL AT FRONT OF LOT, CLEAN ALL MUD AND GRAVEL FROM STREET/CURB -12-10-21- ITEMS STILL NOT CORRECTED- PROVIDE EROSION CONTROL, CLEAN DEBRIS FROM STREET,STORM INLET AND REMOVE PORTA JOHN FROM STORM INLET
---	------	---

Comments: