

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215798
Address: 1609 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Mitchell Schwarz	Failed	Friday, December 10, 2021

Corrective Action Required:

1	Misc	Footing inspection denied- House plans do not Match approved plot plan. Resubmit correct plot plan with rear garage for review showing correct foundation detail, retaining g wall and grade. Do not pour footing.
---	------	---

Comments: