



November 16, 2021

Walker Custom Homes, LLC  
Attn: Jason Walker & Jeff Roberts

Re: 1917 NE Catalina Ave., Lee's Summit, MO (Lot 308, Park Ridge)


Vista Structural Engineering, LLC, was asked to address the following comments called out during the city's rough-in inspection for the house being built at 1917 NE Catalina Avenue:

- **Provide assessment of connection of patio cover beam at right side of dining area** *Please install (1) Simpson SDWC15600 screw down through top plate, into top of LVL beam, as shown on Figure 2*
- **Provide assessment of connection of patio cover beam at left side of dining area** *Please install (1) Simpson SDWC15600 screw down through top plate, into top of LVL beam, as shown on Figure 3*

Our firm appreciates the opportunity to serve you. If you have any questions or if you need anything further, please feel free to contact us.

Sincerely,  
Vista Structural Engineering, LLC

Dennis Heier, P.E.



# VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET  
PORTLAND, OREGON 97229



# VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET  
 PORTLAND, OREGON 97229



Alternate Connection (Figure 2)

# VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET  
PORTLAND, OREGON 97229

- 3 -

PHONE: 971.233.6099  
VISTASTRUCTURAL.COM



Alternate Connection (Figure 3)

# VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET  
PORTLAND, OREGON 97229