

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211033  
Address: 4421 SW TANZANITE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Monday, December 13, 2021

Corrective Action Required:

1	Misc	-final grade and sod -check water meter and siding to grade spacing at time of final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -seal top of A/c disconnect -Provide guard rail at front stoop where more than 30", 36" out -security screws at basement back door
---	------	---

Comments: