CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204747 Address: 4406 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection	ו:	Inspector:	Outcome:	Date:	
Occupancy Inspection - Codes Residential		Mitchell Schwarz	Failed	Friday, November 12, 2021	
Corrective	Action Required:				
1	Misc	-guard rail at front stoo -obtain sprinkler permi	p device on oven e/carbon dioxide detectors not all ran together rail at front stoop as required by section R312.1.1		

Comments: