CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20192738

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Sediment Control (ESC) John DiMauro Passed Friday, December 03,

Inspection 2021

Corrective Action Required:

1 Misc John DiMauro 1/25/2021

Erosion control devices need to be maintained for this project. Gutter protection needs cleaned and silt fence needs to be restored at perimeter and low lying areas to control silt runoff.

The 3 area inlets along the south side of the project need to be protected with inlet devices asap. Mud and silt is running into the storm water collection system.

Comments: