

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213684
Address: 4808 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, December 14, 2021

Corrective Action Required:

1	Misc	-Secure fireplace to framing -Fb basement bathroom wall from fur down ceiling space; Use 3/4" sheathing for fire blocking, not 1/2" sheathing -Install missing I beam column at pocket office -Complete framing at basement bedroom window -Solid block underneath the 3 trimmer studs at fireplace and install 3 studs down to foundation wall
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

****OK TO INSULATE**

Comments: