

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212082
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Not Ready	Tuesday, December 14, 2021

Corrective Action Required:

1	Miscellaneous Correction	Hard lids restrooms & entry vestibule ok to cover Provide cover open J box front of bldg Fire caulk above ceiling south wall above drive thru Address roof access near back door per plan Complete ceiling grid @ rear door above electrical service panel
---	-----------------------------	--

Comments: