

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212070
Address: 209 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Tuesday, December 14, 2021

Corrective Action Required:

1	Miscellaneous Correction	- FRONT PORCH PROVIDE ENGINEERS LETTER ADDRESSING FIELD MODIFICATIONS TO TRUSSES E3,E4,E5, - - COVERED DECK APPROVED OK TO COVER -
---	--------------------------	-------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	Misc	PROVIDE Repairs to trusses front porch per engineers letter Address notched trusses master closet/Garage wall Tighten anchor bolts basement nail exterior wall sheathing per code 6" edge 12" field
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: