

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211584
Address: 2134 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, December 14, 2021

Corrective Action Required:

1	Misc	Pay not ready fees Driveway at 3rd car garage not per plot plan Handrail lower stairs basement shall be 34"-38" Complete gutters/downspouts at front stoop Provide splash blocks 36" from foundation Sump shall discharge 36" from foundation Seal top of meter can & ac disconnect
---	------	---

Comments: