

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213690
Address: 1217 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|----------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Tuesday, December 14, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Have engineer address 2x4 stud walls exceeding 12 ft height at garage, foyer |
|---|------|---|

Comments: