

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210103
Address: 2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|------------|----------|----------------------------|
| Sanitary Sewer - Camera Test | Adam Nacke | Partial | Tuesday, December 14, 2021 |

Informational:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | 12-14-21 AN Holthouse crew laying water main NE park springs ter installed the pipe with some major deflection in it. The crew did not install the 11 1/4 bends according to the plans. I informed the crew that they needed to fix it and they DID. . |
|---|--------------------------|--|

Comments: