

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Failed	Tuesday, December 14, 2021

Informational:	
1	THIRD FLOOR
	-AREAS APPROVED-
	BUILDING C COMPLETE
	BUILDING B COMPLETE
	BUILDING A COMPLETE EXCEPT ELEVATOR

Informational:	
2	SECOND FLOOR
	-AREAS APPROVED-
	BUILDING C: COMPLETE
	BUILDING B: COMPLETE
	BUILDING A: COMPLETE EXCEPT AT ELEVATOR

Informational:

3 FIRST FLOOR

-AREAS APPROVED-

BUILDING C
COMPLETE

BUILDING B
COMPLETE

BUILDING A
COMPLETE

****MCAL BUILDING***
COMPLETE EXCEPT AS NOTED:

-165- RC OK

-164- COMPLETE RATED LAYER AT DISHWASHER HOOD, RC OK

Corrective Action Required:

4 Miscellaneous
Correction

-SEAL GAPS IN BLOCK COURSES INSIDE ELEVATOR SHAFT
-COMPLETE SCREW PATTERN AND SEAL GAPS AND PENETRATIONS AT
MECHANICAL ROOM 165

Corrective Action Required:

5 ELEVATOR 1

-FUR OUT WALLS OK
-RC AT CEILING OK

Comments: