

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

December 06, 2021

INNOVATIVE DESIGN & RENOVATION
8011 PASEO #201
KANSAS CITY, MO 64131

Permit No: PRCOM20216110
Project Title: TOKYO GRILLE
Project Address: 3528 SW MARKET ST, LEES SUMMIT, MO 64082
Parcel Number: 70500031400000000
Location / Legal: SUMMITCREST PLAZA LOT 1--- LOT 1
Description:
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR FOOD AND DRINK INC BARS, RESTAURANTS, BANQUET HALLS
Description: CHANGE OF TENANT FOR NEW RESTAURANT

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is for informational purposes.

2. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

DEVELOPMENT SERVICES

Action required: Comment is for informational purposes.

3. ICC A117.1 404.2.5 - Two doors or gates in series. Distance between two hinged or pivoted doors or gates in series shall be 48 inches minimum plus the width of any door or gate swinging into the space. The space between the doors and gates shall provide a turning space.

Action required: Provide compliant turning space in vestibule. (or remove vestibule which we do not require)

Response: The vestibule has been removed.

4. ICC A117.1 Section 404.2.3.2 Swinging Doors and gates. Swinging doors and gates shall have maneuvering clearances complying with Table 404.2.3.2.

Action required: Provide minimum 54" clearance at approach to entry vestibule. re: figure 404.2.3.2 (f)

Response: The vestibule has been removed.

5. 2018 IMC 507.2.6 Clearances for Type I hood. A Type I hood shall be installed with a clearance to combustibles of not less than 18".

Exceptions:

1. Clearance shall not be required from gypsum wallboard or ½ inch or thicker cementitious wallboard attached to noncombustible structures provided that a smooth, cleanable, nonabsorbent and noncombustible material is installed between the hood and the gypsum or cementitious wallboard over an area extending not less than 18 inches in all directions from the hood.
2. Type I hoods listed and labeled for clearances less than 18 inches in accordance with UL 710 shall be installed with the clearances specified by such listings.

Action required: Specify installation of metal studs in wall behind and 18" adjacent to Type I hood. (or provide verification that the existing construction is non-combustible) **Response: The studs behind the hood are metal. However, the hood has a 1" thick material that allows it to be placed next to the wall. Reference HOODSMART hoods.**

6. 2018 IMC 602.2.1 Materials within plenums. Except as required by Sections 602.2.1.1 through 602.2.1.5, materials within plenums shall be noncombustible or shall be listed and labeled as having a flame spread index of not more than 25 and a smoke-developed index of not more than 50 when tested in accordance with ASTM E84 or UL 723. (see code section for exceptions)

Action required: PVC piping is specified for DWV but mechanical design is not clear as to whether this is a plenum or hard ducted return. Clarify.

Response: All of the return air is ducted.

7. 2018 IBC 1606.2 Design dead load. For purposes of design, the actual weights of materials of construction and fixed service equipment shall be used. In the absence of definite information, values used shall be subject to the approval of the building official.

Action required: Provide engineer's report or design to verify that existing roof structure will support additional load imposed by new equipment. **Response: The equipment consist of exhaust fans nd makup air fans just like ones on the adjacent space. Each weigh about 100 lbs each. The purlins will support the lite weight fans.**

8. 2017 NEC Article 210.63 Heating, Air-Conditioning, and Refrigeration Equipment Outlet. A 125-volt, single-phase, 15- or 20-ampere-rated receptacle outlet shall be installed at an accessible location for the servicing of heating, air-conditioning, and refrigeration equipment. The receptacle shall be located on the same level and within 25 feet of the heating, air-conditioning, and refrigeration equipment. The receptacle outlet shall not be connected to the load side of the equipment disconnecting means.

DEVELOPMENT SERVICES

Action required: Provide receptacle(s) near new roof mounted equipment to comply. (or provide verification of existing)

Response: The outlet is specified on the drawings in a note on the mechanical plan.

Fire Plan Review

Reviewed By: Michael Weissenbach

Rejected

1. 2018 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

(Verified At Inspection)

Post occupant load signage at 29.

Response: An occupant load sign will be posted inside the space for 29.

2. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

(Action Required)

Any modifications to the fire alarm system, provide PE stamped electronic shop drawings to mike.weissenbach@cityofls.net

Note: Type 1 hood to be tied to the alarm system.

Response: A note has been provided to attach the hood to the fire alarm panel.

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications to the fire sprinkler system, provide PE stamped electronic shop drawings to mike.weissenbach@cityofls.net

Response: The fire sprinkler installer will provide plans for the fire sprinkler modifications.

4. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hood trip and alarm test.

Response: A note has been provided to schedule the hood trip and alarm test.

5. 2018 IFC 904.11.5- Portable fire extinguishers for commercial cooking equipment. Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.

(Action Required)

Provide 1 K-Class extinguisher. Placement to be made by the manual pull.

Response: The fire extinguisher will be noted on the plans to be at the manual pull station.

6. (Action Required)

2018 IFC 5307.3

Insulated liquid carbon dioxide systems with more than 100 pounds of carbon dioxide used in beverage dispensing applications shall comply with Section 5307.3.1.

DEVELOPMENT SERVICES

Provide specs and placement of tank. Gas detection may be required.

Response: The specs and placement of the tank will be provided by the installer to the City Before installation.

7. (Informational Purposes)

A Knox Box is not required for the space.

Response: The note has been removed about the Knox Box.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.