

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211430
Address: 134 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Not Ready	Wednesday, December 15, 2021

Corrective Action Required:

1 Misc

Corrective Action Required:

2	DCM3 ESC	12-15-21
	REQUIRED 2 DAY	*NOT READY FEE ASSESSED*

EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.

-PROTECT STORM INLET, REMOVE PORTA JOHN FROM TOP OF INLET,
CLEAN GUTTER BUDDY AND REMOVE DEBRIS FROM INLET-SEE UPLOADED
PHOTO

Comments: