

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212305
Address: 2122 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Wednesday, December 15, 2021

Corrective Action Required:

1	DCM2 ESC	12-15-21
	DEFICIENT	-Maintain silt fence at front of lot, clean debris spilled over curb
	INSTALLATION	

Comments: