

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20210481

Address: 2550 SW 3RD ST, LEES SUMMIT, MO 64081141 NW MORTON DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ronald Paynter	Partial	Wednesday, December 15, 2021

Corrective Action Required:

1	Misc	Someone saw cut the existing curbing at the wrong locations and replaced it with the same curbing and ADA ramp. They needed a depressed curb with the ADA ramp. This could of been avoided if they would of called in a pre-inspection. Curbing and ramp need to be removed and replaced. RP 11-29-21
---	------	---

Corrective Action Required:

2	Misc	Curbing needs to be removed joint to joint. ADA ramp can be altered to match roadway slope and turning space. RP 12-3-21
---	------	--

Informational:

3	Misc	Curbing was removed joint to joint. Forms were placed and aggregate was present and compacted. RP 12-15-21
---	------	--

**Comments:**