

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20212483  
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Wednesday, December 15, 2021

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	*12-15-21 -CORRECTIONS REQUIRED WITHIN 2 BUSINESS DAYS- -NO FURTHER INSPECTIONS UNTIL IN COMPLIANCE - MAINTAIN GUTTER BUDDY REMOVE SEDIMENT BUILD UP, CLEAN DEBRIS SPILLED OVER CURB LINE, PROTECT STORM INLET, REMOVE PORTA JOHN FROM TOP OF INLET
---	---------------------------------------	--

**Comments:**