

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210623  
Address: 2118 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, December 15, 2021

Corrective Action Required:

1	Miscellaneous Correction	INSTALL FURNACE COMPLETE GAS LINES PROVIDE GAUGE WITH MINIMUM 10 PSI FOR 15 MINUTES
---	--------------------------	--

**Comments:**