



CIVIL ENGINEERING CONSULTANTS

1805 WATERS ROAD

HARRISONVILLE

MISSOURI

64701

316-380-5150

FACSIMILE: 816-884-3250

EMAIL: MAIL@REOENGINEERING.COM

December 10, 2021

Attn: Brian Higginbotham
Kevin Higdon Construction
P.O. Box 847
Lee's Summit, MO 64063

RE: R.E.O. Project 21-051-01
1809 SW Sage Canyon
Lee's Summit, MO

Dear Mr. Higginbotham,

We are providing herewith modification to the residential construction at the above referenced plan. Specifically, below the interior wall of the Master Bedroom, provide three (3) ~ 1.75"x11.875" LVL members to support the roof bracing to the top of the wall. Provide a three-ply girder hanger at the interior end of the member at the upset beam.

This member supports roof purlin bracing within the attic space for the gable sidewall style roof construction. If there are any questions regarding this analysis, please contact our Offices.

Very Truly Yours,

R.E.O. ENGINEERING, P.C.

By: , President
Aaron D. Obermiller, P.E.

