

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211043  
Address: 1426 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Wednesday, December 15, 2021

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	*12-15-21 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL IN COMPLIANCE -PROVIDE GRAVEL FILTER AT FRONT OF LOT, RESTORE SILT FENCE AT PERIMETER, CLEAN TRASH AND DEBRIS FROM LOT, STREET AND ADJACENT PROPERTY
---	----------------------------	--

**Comments:**