

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211432
Address: 3105 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, December 15, 2021

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -span rafters properly, glued end joints throughout not correct - (SUBMITTED DOCUMENTATION UNDER REVIEW)
-fireblock deadspace at stair wall master bed closet - area open to attic right of deadspace closet
-Tempered glass required at great room windows at fireplace and basement den, less than 18" from floor
-Install all exterior doors
-address exterior walls not tied together at top plate, kitchen breakfast, master bedroom
-fireblock between studs at wall bump outs throughout basement den, bedroom, closet, open to joist space at top plate |
|---|------|--|

OK TO INSULATE

Comments: