

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20214153

Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081
2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	Ronald Paynter	Partial	Wednesday, December 15, 2021

Informational:

1	Misc	They laid over 1,000 tons AB3 6 inches thick for Black Twig. RP 12-14-21
---	------	--

Informational:

2	Misc	They laid 6 inches of AB3 for building #2 parking lot. RP 12-15-21
---	------	--

Comments: