

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Ronald Paynter	Passed	Thursday, December 16, 2021

Corrective Action Required:

1	Misc	9-27-21 8:00 AN Pressure test 4psi between 10min and 7:30min MH 9-4 to 3-1 passed. MH 2-2 to 2-1 passed MH 3-1 to 3-2 passed. MH 2-1 to 1-2 passed MH 3-2 to 3-3 passed. MH 2-3 to 2-2 passed MH 1-6 to 1-5 passed. MH 4-5 to 4-4 passed MH 1-5 to 1-4 passed. MH 4-4 to 4-3 FAILED start for 30days is 9-27-21 MH 1-4 to 1-3 passed. MH 4-3 to 4-2 passed MH 1-3 to 1-2 passed. MH 4-2 to 4-1 passed MH 1-2 to 1-1 passed. MH 4-1 to EX MH 2 passed MH 1-1 to 1-0 passed
---	------	--

Informational:	
2	Misc Passed all testing

Comments: