

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20211582  
**Address:** 4417 SW ALABASTER CIR, LEES SUMMIT, MO 64082  
**Inspected On:** Thursday, December 16, 2021  
**Inspected By:** Patrick Schonfeldt  
**Expiration Date:** 1/17/2022 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Temporary C of O	Thursday, December 16, 2021

**Corrective Action Required:**

- |   |      |  |
|---|------|--|
| 1 | Misc | -Resolve outstanding inspection fees before final c of o<br>-sidewalk per approved plot plan<br>-min 6" clearance required between sod and siding - see rear of house<br>-(2) through bolts at each post/beam connection<br>-nail all joist hangers at deck<br>-install angle clips at outer ply of beam at deck |
|---|------|--|

OK FOR TCO - TCO EXPIRES 1/17/22