CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210592

Address: 134 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

Inspected On: Thursday, December 16, 2021

Inspected By: Michael Harkins

Expiration Date: 1/17/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Michael Harkins Temporary C of O Thursday,

Codes Residential December 16, 2021

Corrective Action Required:

1 Miscellaneous Provide sod & splash blocks

Correction Seal top exterior light fixtures

Provide gutters & downspouts

OBTAIN LAWN IRRIGATION PERMIT SUBMIT BACK-FLOW

CERTIFICATION