

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212185  
Address: 1809 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:         | Outcome: | Date:                       |
|---|--------------------|----------|-----------------------------|
| <b>All Rough Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Thursday, December 16, 2021 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -seal all penetrations through air returns - (ceiling) basement<br>-fireblock between top plates basement wall<br>-fireblock vertical every 10' between framing/foundation at basement wall |
|---|------|---|

**Comments:**