

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20193055  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:   | Outcome: | Date:                      |
|----------------------------|--------------|----------|----------------------------|
| <b>Street - Wedge Lift</b> | John Jackson | Partial  | Monday, September 21, 2020 |

Informational:

1 Misc

On Saturday, 9-19-2020. Thorne and Son asphalt placed Base lift of asphalt on Princeton street and placed private parking lot's partial base lift as well.

On Thursday, 12-16-2021. Phillips Asphalt Placing Base asphalt on parking lot at various areas through parking lot. Superintendent was notified temp was only 46 degrees and does not meet cities temp to lay surface asphalt.

**Comments:**