



Saint Luke's East Hospital

Saint Luke's ED OFFICE ADDITION 80 NE Saint Luke's Blvd Lee's Summit, MO 64086

P R O J E C T T E A M

ARCHITECT
ACI BOLAND, INC.

1710 WYANDOTTE STREET
KANSAS CITY, MO 64108

PHONE 816.763.9600
FAX 816.763.9757

MEP ENGINEER
IMEG Corp.


1600 Baltimore, Suite 300
Kansas City, MO 64108

PHONE 816.842.8437
FAX 816.842.6441


ABBREVIATIONS

| | | | | | |
|--------|-----------------------------|---------|-----------------------|--------|------------------------|
| AC. | ACOUSTIC/ACOUSTICAL | FLOR. | FLUORESCENT | PTD. | PAINTED |
| ADD. | ADDENDUM | FTG. | FOOTING | PG. | PAGE |
| ADDN. | ADDITION | FND. | FOUNDATION | PLAM. | PLASTIC LAMINATE |
| ABC | AGGREGATE BASE COURSE | FR. | FRAME | PR. | PAIR |
| ABF. | ABOVE FINISH FLOOR | F.H.C. | FIRE HOSE CAB. | PNL. | PANEL |
| AGG. | AGGREGATE | FV. | FIELD VERIFY | PTN. | PARTITION |
| AGC. | AIR CONDITIONING | | | PENNY | PENNY |
| AL. | ALUMINUM | GA. | GAUGE | PL. | PLATE |
| ALT. | ALTERNATE | GL. | GLASS / GLAZING | PLBG. | PLUMBING |
| A.B. | ANCHOR BOLT | GD. | GRADE | PLYWD. | PLYWOOD |
| & | AND | G. | GRAM | PT. | POINT |
| ARCH. | ARCHITECT | GRL. | GRILLE | P.S.I. | POUNDS PER SQ. IN. |
| ASP. | ASPHALT | GRD. | GRID | P.S.F. | POUNDS PER SQ. FT. |
| @ | AT | GND. | GROUND | P.C. | PRECAST |
| ACT. | ACOUSTIC CEILING TILE/PANEL | G.S. | GALVANIZED STEEL | P.L. | PROPERTY LINE |
| ∠. | ANGLE | GYP. | GYPSONUM BOARD | | |
| | | | | R. | RISER, RISERS |
| BLKG. | BLOCKING | H.R. | HAND RAIL | RAD. | RADIUS |
| BSMT. | BASEMENT | HDN. | HARDENER | R.D. | ROOF DRAIN |
| BM. | BEAM | HDW. | HARDWARE | RB. | RESILIENT BASE |
| B.M. | BENCHMARK | HDWD. | HARDWOOD | RE. | REFER TO |
| BD. | BOARD | HTR. | HEATER | REG. | REGISTER |
| B.O. | BOTTOM OF | HT. | HEIGHT | REQD. | REQUIRED |
| BLDG. | BUILDING | H.P. | HIGH POINT | REV. | REVISION |
| | | H.M. | HOLLOW METAL | RFG. | ROUGH |
| CABT. | CABINET | HORIZ. | HORIZONTAL | RGH. | ROUGH |
| C.I.P. | CAST IN PLACE | H.B. | HOSE BIB | RM. | ROOM |
| C.B. | CATCH BASIN | H.W. | HOT WATER | RND. | ROUND |
| CLG. | CEILING | | | R.O. | ROUGH OPENING |
| CEM. | CEMENT/CEMENTITIOUS | | | SCHED. | SCHEDULE |
| CG. | CENTIGRAM | IN. | INCH / INCHES | S.C. | SEALED CONCRETE |
| CM | CENTIMETER | I.D. | INSIDE DIAMETER | SCR. | SCREW |
| CL | CENTER LINE | INSUL. | INSULATION | SECT. | SECTION |
| CER. | CERAMIC | INT. | INTERIOR | SEL. | SELECT |
| C.T. | CERAMIC TILE | INV. | INVERT | SHG. | SHEATHING |
| CHAN. | CHANNEL | JAN. | JANITOR | SHT. | SHEET |
| C. | CHANNEL | JT. | JOINT | SDG. | SIDING |
| CLR. | CLEAR | JST. | JOIST | SIM. | SIMILAR |
| C.O. | CLEAN OUT | K.P. | KICK PLATE | SLDG. | SLIDING |
| CLOS. | CLOSET | LAM. | LAMINATED | SM. | SMOOTH |
| COL. | COLUMN | LB. | POUND | SPEC. | SPECIFICATION |
| CONC. | CONCRETE | LDO. | LANDING | SQ. | SQUARE |
| CONN. | CONNECTION | LTH. | LATH | ST. | STAINED |
| CONST. | CONSTRUCTION | LAV. | LAVATORY | STD. | STANDARD |
| C.J. | CONTROL JOINT | LG. | LENGTH | S.S. / | STAINLESS STEEL |
| CONT. | CONTINUOUS | LOC. | LOCATION | STRUC. | STRUCTURE |
| CONTR. | CONTRACTOR | LT. | LIGHT | SUSP. | SUSPENDED |
| CORG. | CORRUGATED | L.W.C. | LIGHT WEIGHT CONCRETE | SW.BD. | SWITCHBOARD |
| CTR. | COUNTER | LVR. | LOUVER | SYS. | SYSTEM |
| CTBK. | COUNTERBANK | LOC. | LOCATION | | |
| C.M.U. | CONCRETE MASONRY UNIT | | | T. | TREAD |
| | | M.O. | MASONRY OPENING | T.C. | TOP OF CURB |
| D.P. | DAMP PROOFING | MFR. | MATERIAL MANUFACTURER | T.G. | TEMPERED GLASS |
| DB. | DECIBEL | MB. | MARKER BOARD | T.O. | TOP OF |
| DIAG. | DIAGONAL | MECH. | MECHANICAL | T.S.D. | TOP OF STEEL DECK |
| DIAM. | DIAMETER | MTL. | METAL | T.W. | TEACHERS WARDROBE |
| DIM. | DIMENSION | MTL. | METAL LATH | TYP. | TYPICAL |
| DISP. | DISPENSER | M. | METER | | |
| DWL. | DOWEL | M.D.G. | MINIMUM MOLDING | U.O.N. | UNLESS OTHERWISE NOTED |
| DN. | DOWN | MULL. | MULLION | | |
| D.S. | DOWNSPOUT | | | V. | VENT |
| DWG. | DRAWING | | | VERT. | VERTICAL |
| | | N.G. | NATURAL GRADE | V.G. | VERTICAL GRAIN |
| EA. | EACH | NOM. | NOMINAL | VEST. | VESTIBULE |
| ELEC. | ELECTRIC | N.I.C. | NOT IN CONTRACT | V.C.T. | VINYL COMPOSITION TILE |
| E.W.C. | ELECTRIC WATER COOLER | N.T.S. | NOT TO SCALE | VCP. | VITREOUS CLAY PIPE |
| EL. | ELEVATION | NO. / # | NUMBER | | |
| ELEV. | ELEVATOR | | | W.W.M. | WELDED WIRE MESH |
| EQ. | EQUAL | | | W.C. | WATER CLOSET |
| EQUIP. | EQUIPMENT | OBS. | OBSCURE | W.H. | WATER HEATER |
| EXH. | EXHAUST | O.C. | ON CENTER | W.F. | WIDE FLANGE |
| EXPAN. | EXPANSION | OPNG. | OPENING | WI. | WITH |
| E.J. | EXPANSION JOINT | O.A. | OVERALL | W/O. | WITHOUT |
| EXIST. | EXISTING | O.D. | OUTSIDE DIAMETER | WD. | WOOD |
| EXT. | EXTERIOR | O.F.S. | OVERFLOW SCUPPER | WOW. | WINDOW |
| | | O.F.D. | OVERFLOW DRAIN | W.W. | WINDOW WALL |
| FT. | FEET / FOOT | O.H.D. | OVERHEAD DOOR | | |
| FIN. | FINISH | | | | |
| FIXT. | FIXTURE | | | | |
| FL. | FLASHING | | | | |
| FLR. | FLOOR | | | | |
| F.D. | FLOOR DRAIN | | | | |

LOCATION PLAN



VICINITY PLAN



GENERAL NOTES

- ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH A.D.A. REQUIREMENTS AND ALL APPLICABLE LOCAL, STATE, AND FEDERAL BUILDING CODES AND REGULATIONS.
- THE CONTRACTOR IS RESPONSIBLE FOR OBTAINING ALL NECESSARY BUILDING PERMITS.
- THE GENERAL CONTRACTOR AND SUBCONTRACTORS SHALL FIELD VERIFY EXISTING CONDITIONS AND NOTIFY THE ARCHITECT OF ANY INCONSISTENCIES OR DISCREPANCIES WITH THE PROJECT DOCUMENTS. ACCESS TO THE SITE AND/OR SPACE UNDER CONSTRUCTION DURING BIDDING AND CONSTRUCTION SHALL BE COORDINATED WITH THE OWNER.
- DO NOT SCALE DRAWINGS.
- THE WORD "ALIGN" AS USED IN THESE DOCUMENTS SHALL SUPERSEDE ANY DIMENSIONAL INFORMATION GIVEN.
- TYPICAL DIMENSIONS ARE TO FACE OF CONCRETE, DRYWALL, CURTAIN WALL, ETC., OR TO COLUMN CENTERLINE. DIMENSIONS AT WINDOWS ARE TYPICALLY TO FACE OF FRAME. REFER TO PLAN DETAILS FOR ADDITIONAL INFORMATION.
- THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR EXAMINING AND CONFIRMING ALL SUBSTRATE CONDITIONS WHERE NEW MATERIALS ARE APPLIED. THE SUBSTRATE SHALL BE SMOOTH AND FREE OF DEFECTS AND SHALL CONFORM TO THE REQUIREMENTS OF THE FINISHED MATERIAL MANUFACTURERS RECOMMENDATIONS.
- THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR CLEAN-UP.
- CONTRACTOR TO PROVIDE ALL REQUIRED LABOR, MATERIAL, AND EQUIPMENT NECESSARY TO MEET AND COMPLETE THE REQUIREMENTS OF THE NEW CONSTRUCTION.
- IF MATERIAL SUSPECTED OF CONTAINING HAZARDOUS MATERIALS ARE ENCOUNTERED, DO NOT DISTURB. IMMEDIATELY NOTIFY ARCHITECT AND OWNER. OWNER SHALL COORDINATE WITH CONTRACTOR ON THE REMOVAL OF SUCH ITEMS. WORK MAY PROCEED AFTER HAZARDOUS MATERIAL HAS BEEN REMOVED.
- UPON VERIFICATION OF THE EXISTING CONDITIONS, THE CONTRACTOR SHALL DETERMINE AND RECOMMEND THE BEST ACTION TO MINIMIZE THE EXTENT OF REMOVAL WORK FOR INSTALLATION OF NEW WORK.

SHEET INDEX - OFFICE

| SHEET NUMBER | SHEET NAME |
|--------------|----------------------------------|
| ARCHITECTURE | |
| A0.1.2 | COVER SHEET |
| A0.2.2 | LIFE SAFETY PLAN |
| A2.1.2 | OFFICE PLANS |
| A02.1.2 | OFFICE DEMO AND DETAILS |
| MECHANICAL | |
| M000.2 | MECHANICAL COVER SHEET |
| M001.2 | FIRST FLOOR - MECH PIPING |
| M211.2 | FIRST FLOOR - VENTILATION |
| M410.2 | VENTILATION AND PIPING DETAILS |
| M510.2 | SCHEDULES AND CONTROL DIAGRAMS |
| ELECTRICAL | |
| E000.2 | ELECTRICAL COVERSHEET |
| E201.2 | FIRST FLOOR - LIGHTING - OFFICES |
| E211.2 | FIRST FLOOR - POWER - OFFICES |
| E221.2 | FIRST FLOOR - SYSTEMS - OFFICES |

**Saint Luke's
East Hospital**
Saint Luke's ED Office Renovation
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

Date 11/12/21
Job Number 3-21024
Drawn By Author
Checked By Checker

Revision
Number Date Description
7 12/10/21 ASI #5 Office

A0.1.2
© 2021 ACI/BOLAND, Inc.

COVER SHEET

RELEASED FOR CONSTRUCTION
Development Services Department
Summit, Missouri
12/10/2021



Samuel K. Beckman - Architect
License - Missouri EA-2011012130

ACI BOLAND
ARCHITECTS

1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:


MEP CONSULTANT
IMEG Corp.
1600 Baltimore, Suite 300
Kansas City, Missouri 64108
T: 816.842.8437
Licensee's Certificate of Authority Number:
Kansas #E-34



| CODE SUMMARY | |
|---|--|
| Project Construction Purpose: Interior office renovation | |
| Project Address: Saint Luke's Lee's Summit 80 NW Saint Luke's Blvd Lee's Summit, MO 64063 | |
| Code Information 2018 International Building Code 2018 International Plumbing Code 2018 International Mechanical Code 2018 International Fuel Gas Code 2018 International Fire Code 2017 National Electrical Code 2009 ICC/ANSI A117.1 as amended and adopted by the City of Lee's Summit | |
| State of Missouri Dept. of Health & Environment references the following codes: 2012 NFPA 101 Life Safety Code (LSC) 2014 FGI Guidelines for Design & Construction of Hospitals & Outpatient Facilities | |
| Owner Information Saint Luke's Lee's Summit 80 NW Saint Luke's Blvd Lee's Summit, MO 64063 | |
| Designer Information ACI Boland Architects 1710 Wyandotte St. Kansas City, MO 64108 Phone: (816) 763-9600 Fax: (816) 763-9727 | |
| Local Authority Responding Fire Service: Lee's Summit Fire Department Local Building Inspector: Lee's Summit, MO Codes Administration Department | |
| Type of Construction: | Type I-A - Section 602.2 (Type I - 332 Sprinklered - Section 18.1.6.1) |
| Area of Renovation: | 650+- SF |
| Occupancy Group: | I-2 - Section 308.3 |
| Occupant Load: | 100 gross Table 1004.5 Total Square Footage: 650 SF / 100 = 7 occupants total |
| Required Fire Resistance Ratings (in hours) Per NFPA 101 A.9.7.1.2: | |
| Exterior Bearing Walls | 3 HR |
| Interior Bearing Walls | 3 HR |
| Primary Structural Frame | 3 HR |
| Floor Construction | 2 HR |
| Roof Construction | 1 1/2 HR |
| Interior non-bearing walls | 0 HR |
| Active Fire Safety Features: | |
| - Fire Alarm System - The fire alarm system is specified as an addressable type system. The device type and locations are per the applicable codes as well as ADA requirements. | |
| - Smoke Control System - All ductwork penetrating smoke rated walls will have a smoke or combination fire/smoke damper as indicated on construction documents. These dampers will close upon detection of smoke by the area smoke detectors or duct smoke detectors in the air handling units. | |
| - Fire Sprinkler System - Specified to be per NFPA 13. The sprinkler heads are specified to be quick response type. | |
| - Emergency Lighting and Power - Emergency lighting, life safety and critical loads will receive power from a backup generator located outside the main electrical room. | |
| - Illuminated Exit Signs | |
| Passive Fire Safety Features: | |
| - Smoke Compartments no greater than 22,500 SF | |

PARTITION GENERAL NOTES

1. UNLESS NOTED OTHERWISE, ALL INTERIOR METAL STUDS ARE 3 5/8" THICK. REFER TO SUFFIX SCHEDULE BELOW FOR LOCATIONS OF METAL STUDS OTHER THAN 3 5/8" THICK. NOTE: STUD THICKNESS (GAUGE) MUST CONFORM TO MANUFACTURER'S RECOMMENDATIONS FOR SPAN HEIGHT OF STUD.
 2. WHERE THE PARTITION TYPE INDICATION IS SHOWN WITH A NUMERICAL SUFFIX, THE METAL STUD THICKNESS SHALL BE AS SCHEDULED BELOW:
- | SUFFIX | MTL. STUD THICKNESS |
|--------|---------------------|
| 1 | 1-5/8" MTL. STUDS |
| 2 | 2-1/2" MTL. STUDS |
| 3 | 6" MTL. STUDS |
3. UNLESS NOTED OTHERWISE, ALL INTERIOR DRYWALL PARTITIONS INDICATED ON THE FLOOR PLAN DRAWING ARE TYPE 'A' PARTITIONS. WHERE OCCURS, RATINGS ARE AS INDICATED ON THE LIFE SAFETY PLANS.
 4. UNLESS NOTED OTHERWISE, ALL INTERIOR MASONRY PARTITIONS INDICATED ON THE FLOOR PLAN DRAWING ARE TYPE 'B' PARTITIONS. WHERE OCCURS, RATINGS ARE AS INDICATED ON THE LIFE SAFETY PLANS.
 5. ALL STUDS ARE CONTINUOUS FROM FLOOR STRUCTURE TO CEILING STRUCTURE UNLESS NOTED OTHERWISE.
 6. METAL STUDS ARE SPACED @ 16" O.C. MAX., UNLESS NOTED OTHERWISE.
 7. UNLESS NOTED OTHERWISE, ALL GYPSUM BOARD IS TO BE 5/8" THICK "FIRECODE".
 8. THE LOCATION OF A CHANGE IN THE PARTITION TYPE IS INDICATED BY A WALL TAG.
 9. THE CORRESPONDING RATED ASSEMBLIES ARE INDICATED BELOW THE PARTITION TYPES.
 10. PARTITION TYPE DESIGNATIONS ARE INDICATED ON THE FLOOR PLAN DRAWINGS.
 11. PARTITION TYPES DO NOT INCLUDE APPLIED FINISHES CALLED FOR IN THE ROOM FINISH SCHEDULE.
 12. AT PARTITION TYPES WHERE MTL. STUDS ARE EXPOSED ON ONE OR BOTH SIDES, CUT STUD 1/4" SHORT AND SCREW BOTH SIDES TO MTL. RUNNER TRACK.



RELEASED FOR CONSTRUCTION

Development Services Department
St. Louis, Missouri
12/10/2021

Samuel K. Beckman - Architect
License - Missouri EA-2011012130

ACI BOLAND ARCHITECTS

1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:

MEP CONSULTANT

IMEG Corp.
1600 Baltimore, Suite 300
Kansas City, Missouri 64108
T: 816.842.8437
Licensee's Certificate of Authority Number:
Kansas #E-34

Saint Luke's East Hospital

Saint Luke's ED Office Renovation
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

| | |
|------------|----------|
| Date | 11/12/21 |
| Job Number | 3-21024 |
| Drawn By | Author |
| Checked By | Checker |

| | | |
|----------|----------|---------------|
| Revision | | |
| Number | Date | Description |
| 7 | 12/10/21 | ASI #5 Office |

A0.2.2

© 2021 ACI/BOLAND, Inc.

LIFE SAFETY PLAN

DOOR SCHEDULE - OFFICE

| DOOR # | ROOM NAME | DOOR INFORMATION | | | FRAME INFORMATION | | LABEL (MIN) | HRDWR SET | OPENING DETAIL | | REMARKS | REV # |
|-----------|---------------------------|------------------|--------|-------|-------------------|-------|-------------|-----------|----------------|------|-----------------------------------|--------|
| | | WIDTH | HEIGHT | ELEV. | MATL. | ELEV. | | | HEAD | JAMB | | |
| 02-1B053B | EMERGENCY RESPONSE OFFICE | 3'-0" | 7'-0" | F | WD | 1 | HM | 0 hr | 1 | E1 | E1 | OFFICE |
| 02-1B053C | CORRIDOR | 3'-0" | 7'-0" | F | WD | ETR | HM | 0 hr | ETR | ETR | REUSE EXISTING FRAME AND HARDWARE | |
| 02-1B053D | OFFICE | 3'-0" | 7'-0" | F | WD | 1 | HM | 0 hr | 1 | E1 | E1 | OFFICE |
| 02-1B053E | OFFICE | 3'-0" | 7'-0" | F | WD | 1 | HM | 0 hr | 1 | E1 | E1 | OFFICE |
| 02-1B053F | OFFICE | 3'-0" | 7'-0" | F | WD | 1 | HM | 0 hr | 1 | E1 | E1 | OFFICE |

ROOM FINISH SCHEDULE OFFICE

| ROOM NUMBER | ROOM NAME | FLOOR FINISH | BASE FINISH | WALLS | | | | CEILING | NOTES | REV # |
|-------------|---------------------------|--------------|-------------|-------------|-------------|-------------|-------------|---------|---|-------|
| | | | | NORTH | EAST | SOUTH | WEST | | | |
| 02-1B053B | EMERGENCY RESPONSE OFFICE | LVT-1 | RB-2 | PT-8 | PT-1 | PT-1 | PT-1 | ACT-1 | FURNITURE EQUIPMENT BY J.A. MARSHALL | |
| 02-1B053D | OFFICE | LVT-1 | RB-2 | PT-1 | PT-1 | PT-8 | PT-1 | ACT-1 | FURNITURE EQUIPMENT BY J.A. MARSHALL | |
| 02-1B053E | OFFICE | LVT-1 | RB-2 | PT-8 | PT-1 | PT-1 | PT-1 | ACT-1 | FURNITURE EQUIPMENT BY J.A. MARSHALL | |
| 02-1B053F | OFFICE | LVT-1 | RB-2 | PT-1 | PT-1 | PT-1 | PT-1 | ACT-1 | FURNITURE EQUIPMENT BY J.A. MARSHALL | |
| 02-1B060 | CORRIDOR | LVT-2 | RB-1 | WP-2 / PT-1 | WP-2 / PT-1 | WP-2 / PT-1 | WP-2 / PT-1 | ACT-1 | MATCH EXISTING CORRIDOR FINISHES - TIE NEW FLOOR, BASE, WALL PROTECTION INTO EXISTING | |

INTERIOR FINISH LEGEND

| MARK | ITEM | MFR. | MODEL/ PATTERN | COLOR | SIZE | REMARKS | REV # |
|----------|-----------------------------------|------------------|---|--------------------|-----------------|--|-------|
| FLOOR | | | | | | | |
| CS-1 | CONCRETE SEALED LUXURY VINYL TILE | PER SPECS | AMTICO WOOD | | | REFER TO ARCHITECTURAL | |
| LVT-1 | LUXURY VINYL TILE | MANNINGTON | AMTICO STONE | | | 4-1/2" X 36" | |
| LVT-2 | LUXURY VINYL TILE | MANNINGTON | AMTICO STONE | | | 18" X 18" | |
| RSF-1 | RESILIENT SHEET FLOORING | ARMSTRONG | MEDANTONE W/ DIAMOND 10 TECHNOLOGY | | | 6'-0" ROLL | |
| RSF-2 | RESILIENT SHEET FLOORING | ARMSTRONG | REJUVENATIONS AMBIGU W/ DIAMOND 10 TECHNOLOGY | | | 6'-7" X UP TO 82" | |
| BASE | | | | | | | |
| IB-1 | INTEGRAL BASE | ARMSTRONG | MEDANTONE, DIAMOND 10 | | | 6" COVE | |
| IB-2 | INTEGRAL BASE | ARMSTRONG | REJUVENATIONS AMBIGU W/ DIAMOND 10 TECHNOLOGY | | | 6" COVE | |
| RB-1 | RESILIENT BASE | ROPPE | PINNACLE PLUS, PROFILE #05 | | | 4-5/8" | |
| RB-2 | RESILIENT BASE | ROPPE | PINNACLE | | | 4" COVE | |
| WALL | | | | | | | |
| CG-2 | CORNER GUARDS | C/S ACRYLYN | SM-20AN-ACRYLYN-4000 | #933 MISSION WHITE | 3" | 90 DEGREE ABOVE BASE TO CEILING / INCLUDE ALL TRIM AND ACCESSORIES PIECES | |
| CG-3 | CORNER GUARDS | C/S ACRYLYN | SSM-25AN-ACRYLYN-4000 | #933 MISSION WHITE | 2" | END WALL ABOVE BASE TO CEILING / INCLUDE ALL TRIM AND ACCESSORIES PIECES | |
| CG-4 | CORNER GUARDS | C/S ACRYLYN | SM-20MN-ACRYLYN-4000 | #933 MISSION WHITE | 3" X 3" | SURFACE 135 DEGREE ABOVE BASE TO CEILING / INCLUDE ALL TRIM AND ACCESSORIES PIECES | |
| PT-1 | PAINT | SHERWIN WILLIAMS | SW7008 | ALABASTER | - | FIELD PAINT, EGGSHELL FINISH | |
| PT-1A | PAINT | SHERWIN WILLIAMS | SW7008 | ALABASTER | - | FIELD PAINT, EPOXY FINISH | |
| PT-4 | PAINT | SHERWIN WILLIAMS | SW7046 | ANAKINOLIS | - | DOOR FRAME PAINT, SEMI-GLOSS FINISH | |
| PT-5 | PAINT | SHERWIN WILLIAMS | SW7008 | ALABASTER | - | CEILING PAINT, FLAT FINISH | |
| PT-7 | PAINT | SHERWIN WILLIAMS | SW6221 | MOODY BLUE | - | ACCENT PAINT, EGGSHELL FINISH | |
| PT-8 | PAINT | SHERWIN WILLIAMS | SW7021 | SILVER MIST | - | ACCENT PAINT, EGGSHELL FINISH | |
| WP-2 | WALL PROTECTION | C/S ACRYLYN | 040 ACRYLYN 4000 | #933 MISSION WHITE | 4" X 10' SHEETS | WALL PROTECTION AT 48" AFF INCLUDING ALL ACCESSORIES | |
| CASEWORK | | | | | | | |
| EB-1 | EDGE BANDING | DOELKEN | #70765 | | | WALNUT HEIGHTS | |
| FLAM-1 | HIGH PRESSURE LAMINATE | WILSONART | #7966K-12 | | | WALNUT HEIGHTS | |
| IS-1 | INTEGRAL SINK | CORIAN | BONE | - | | 30" X 144" SHEET 36" X 144" SHEET | |
| SSF-1 | SOLID SURFACE | CORIAN | CLAM SHELL | - | | 12" 30" X 144" SHEET 36" X 144" SHEET | |
| SSF-2 | SOLID SURFACE | CORIAN | BONE | - | | 1-1/2" 30" X 144" SHEET 36" X 144" SHEET | |
| CEILING | | | | | | | |
| ACT-1 | ACOUSTIC CEILING TILE | USG | RADAR CLIMA PLUS #2210 | WHITE | 2' X 2' | SQUARE EDGE, DOWN DX TEE 15/16" GRID SYSTEM, ALL CAMPUSES - PUBLIC SPACES/BACK OF HOUSE, RE: ROOM FINISH SCHEDULE FOR AREAS W/ HOLD DOWN CLIPS | |
| ACT-2 | ACOUSTIC CEILING TILE | USG | CLEAN ROOM CLIMA PLUS CLASS 100 #56099 (UNPERFORATED) | WHITE | 2' X 2' | VINYL FACED W/ SQUARE EDGE, DOWN DOX 15/16" TEE GRID SYSTEM | |
| MISC. | | | | | | | |
| OC-1 | CUBICLE CURTAIN | - | - | - | - | CUBICLE CURTAIN TO BE OFOI | |
| ETR | EXISTING TO REMAIN | - | - | - | - | - | |
| PM | PATCH TO MATCH | - | - | - | - | - | |

GENERAL ROOM FINISH SCHEDULE NOTES

- A REFER TO FINISH PLAN AND INTERIOR ELEVATIONS FOR WALL FINISHES, WALL PROTECTION, CORNER GUARDS, WINDOW TREATMENTS, FLOOR FINISH APPLICATION AND LOCATIONS
- B ALL SOLID WOOD, WOOD VENEER, AND PLASTIC LAMINATE GRAIN SHALL BE VERTICALLY ORIENTED UNLESS OTHERWISE NOTED
- C DOOR FRAMES, HOLLOW METAL WINDOW FRAMES TO BE PT-4 UNLESS OTHERWISE NOTED
- D ALL FACES AND UNDERSIDES OF SOFFITS AND HEADERS TO BE PT-1 UNLESS OTHERWISE NOTED
- E WALL EXPANSION JOINTS TO BE PT-1 UNLESS OTHERWISE NOTED
- F ALL ELECTRICAL PANELS AND METAL GRILLES SHALL BE PTD TO MATCH ADJACENT WALL SURFACE UNLESS OTHERWISE NOTED
- G ALL COLUMN SURROUND FINISHES TO MATCH ADJACENT WALL SURFACE UNLESS OTHERWISE NOTED
- H WHERE A WALL IS INDICATED TO HAVE PARTIAL OR FULL FT WALL PROTECTION, THE ENTIRE WALL IS TO BE PTD PRIOR TO WALL PROTECTION INSTALLATION
- I EXTEND ALL FINISHES BENEATH, BEHIND, AROUND ALL CASEWORK, EQUIPMENT, SIGNAGE, ETC.
- J ALL WINDOW SILLS TO BE SSF-2
- K REFER TO DETAIL OF TYPICAL ELEVATION OF WALL PROTECTION/CORNER GUARD MOUNTING HEIGHTS SHOWN ON A7.2

GENERAL NOTES

- EXISTING MEPPF DEVICES SHOWN ARE BASED ON EXISTING DRAWINGS AND/OR FIELD OBSERVATIONS. THE OWNER/ARCHITECT DOES NOT GUARANTEE THE ACCURACY/LOCATION OR QUANTITY OF EXISTING DEVICES.
- CONTRACTOR TO PROVIDE ALL REQUIRED LABOR, MATERIAL, AND EQUIPMENT NECESSARY TO MEET AND COMPLETE THE REQUIREMENTS OF THE NEW CONSTRUCTION.
- ALL EXISTING CONSTRUCTION TO REMAIN SHALL BE PATCHED, REPAIRED, AND PREP AS REQUIRED FOR NEW FINISH APPLICATION.
- SEE FINISH SCHEDULE FOR FINISH LOCATION AND SPECIFICATIONS.
- PAINT THE UNDERSIDE OF ALL GYPSUM BOARD CEILINGS, BULKHEADS AND SOFFITS AS NOTED IN THE FINISH SCHEDULE.
- THIS PLAN SHALL BE USED TO COORDINATE THE CEILING LAYOUT WITH MECHANICAL AND ELECTRICAL WORK. VERIFY THE EXACT QUANTITY REQUIRED.
- CONTRACTOR TO REFER TO THE ELECTRICAL PLANS FOR ACTUAL LIGHTING SIZES AND FIXTURE TYPES.
- ALL CEILINGS SHALL BE 9'-0" AFF UNLESS OTHERWISE NOTED.

CEILING LEGEND

| | |
|---|--|
| ○ | RECESSED LED CAN LIGHT FIXTURE RE: ELECT |
| ▨ | 2X4 RECESSED/SURFACE LED LIGHT FIXTURE RE: ELECT |
| ▨ | 2X2/2X4 LAY-IN ACOUSTICAL CEILING |
| ⊠ | SUPPLY AIR GRILLE RE: MECH |
| ⊠ | RETURN AIR OR EXHAUST GRILLE RE: MECH |

KEYNOTES - RCP - OFFICE

| NUMBER | COMMENTS |
|--------|---|
| 6 | THE NEW CEILING INTO EXISTING GRID |
| 7 | NEW CEILING, LIGHTS, AND DIFFUSERS, REF. MECH. AND ELECT. |

FLOOR PLAN LEGEND


| | | | |
|----------|--------------|---|----------------------------|
| ▨ | NOT IN SCOPE | ▨ | NOT IN ARCHITECTURAL SCOPE |
| — | NEW WALL | — | EXISTING WALL |
| DOOR No. | NEW DOOR | — | EXISTING DOOR |

KEYNOTES - FLOOR PLAN - OFFICE


| NUMBER | COMMENTS |
|--------|---|
| 7 | RELOCATED 14M RADIO EQUIPMENT & CABINET |
| 8 | RELOCATED EMERGENCY RADIO EQUIPMENT MOUNTED ON 4" CONCRETE PEDISTAL. COORDINATE SIZE OF PEDISTAL WITH EQUIPMENT, RE: ELECT. |
| 9 | EXISTING DOOR OPENING SIZED FOR NEW WINDOW WITH SOLID SURFACE SILL |
| 10 | RELOCATED 14M RADIO EQUIPMENT CABINET. TOP OF FOLD DOWN WORK SURFACE NOT TO BE HIGHER THAN 34" A.F.F. |
| 11 | RELOCATED EMERGENCY RADIO STORAGE |
| 12 | NEW WORK STATION WITH UPPER CABINETS BY J.A. MARSHALL. UNDER CABINET LIGHTING ON UPPER CABINET |
| 13 | RELOCATED FILE CABINET |

ALTERNATE #1: PROVIDE CLOSED CELL SPRAY FOAM INSULATION ALONG EXISTING BLOCK WALL AT WALL TYPE L3 IN LIEU OF FLUID APPLIED VAPOR BARRIER AND BATT INSULATION.

C2 EXTERIOR ELEVATION
1/4" = 1'-0"



C1 FIRST FLOOR PLAN - RADIO EQUIPMENT
1/4" = 1'-0"



A2 FIRST FLOOR PLAN - OFFICE SUITE
1/4" = 1'-0"



A6 OFFICE SUITE RCP
1/4" = 1'-0"



RELEASED FOR CONSTRUCTION

Development Services Department
Summit, Missouri
02/02/2021

Samuel K. Beckman - Architect
License - Missouri EA-2011012130

ACI BOLD ARCHITECTS

1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:

MEP CONSULTANT

IMEG Corp.
1600 Baltimore, Suite 300
Kansas City, Missouri 64108
T: 816.842.8437
Licensee's Certificate of Authority Number:
Kansas #E-34

Saint Luke's East Hospital

Saint Luke's ED Office Renovation

80 NE Saint Luke's Blvd

Lee's Summit, MO 64086


Date 11/12/21
Job Number 3-21024
Drawn By Author
Checked By Checker

Revision
Number Date Description
7 12/10/21 ASI #5 Office

A2.1.2

© 2021 ACI/BOLAND, Inc.

OFFICE PLANS




WHERE DUST PARTITIONS ARE TO REMAIN THROUGH CONSTRUCTION, THEY SHALL BE CONSTRUCTED OF 3-5/8" METAL STUDS WITH CONTINUOUS TOP AND BOTTOM RUNNERS. PARTITIONS SHALL EXTEND TIGHT FROM FLOOR TO THE EXISTING CEILING OR STRUCTURE ABOVE, AND CORDED AROUND DUCTS, PIPES, ETC., THAT PENETRATE THE PARTITION. THE ENTIRE PARTITION SHALL BE COVERED WITH 5/8" FIRE RATED GYP. BOARD SCREWED TO STUDS. ALL JOINTS BETWEEN SHEATHINGS, AT WALLS, AT FLOORS, CEILINGS, AROUND PIPES, ETC., TAPED AND SEALED TIGHT TO ENSURE DUST-PROOFING.

THE CONTRACTOR SHALL COVER AND SEAL IN A DUST-TIGHT MANNER ALL EXISTING OPENINGS, GRILLES, JOINTS AROUND DOORS AND FRAMES, ETC., WITH FIRE RETARDANT SHEET AND/OR TAPE AS APPROPRIATE WHERE SUCH OPENINGS, ETC., OCCUR IN EXISTING PARTITIONS SEPARATING EXISTING AREAS FROM CONSTRUCTION AREAS. THE CONTRACTOR SHALL MAINTAIN AND REPAIR ANY DUST BARRIERS AS DETERMINED BY, AND TO THE SATISFACTION OF, THE OWNER.

SMOKE TIGHT NON-COMBUSTIBLE CONSTRUCTION PARTITION

1 1/2" = 1'-0"

DEMOLITION LEGEND




KEYNOTES - DEMO PLAN - OFFICE

| NUMBER | COMMENTS |
|--------|---|
| 8 | REMOVE CONCRETE PEDISTAL |
| 9 | REMOVE AND RELOCATE EXISTING HAM RADIO EQUIPMENT TO EMS BREAK ROOM, RE. ELECT. PLANS FOR FINAL LOCATION |
| 10 | REMOVE AND RELOCATE EXISTING EMERGENCY RADIO EQUIPMENT TO MECHANICAL PENTHOUSE, RE. ELECT. PLANS FOR FINAL LOCATION |
| 11 | REMOVE PORTION OF EXISTING WALL, FLOOR, BASE AND CEILING TO COORDINATE WITH NEW CONSTRUCTION |
| 12 | REMOVE EXISTING DOOR AND FRAME, VERIFY WITH OWNER IF DOOR OR HARDWARE NEEDS TO BE SALVAGED |
| 13 | PATCH AND PREP OPENING FOR NEW INFILL AND WINDOW |
| 14 | REMOVE EXISTING MISC. WALL MOUNTED ITEMS, COORDINATE WITH OWNER WHAT NEEDS TO BE SALVAGED |
| 15 | REMOVE EXISTING FLOOR, BASE, CEILING, AND LIGHTS TO COORDINATE WITH NEW CONSTRUCTION |
| 16 | REMOVE AND REPLACE EXISTING DOOR, REINSTALL EXISTING DOOR HARDWARE |
| 17 | TEMP. CONST. ENTRANCE. COORDINATE FINAL LOCATION WITH OWNER |


GENERAL DEMOLITION NOTES

- PLANS REPRESENTS DEMOLITION INTENT. ITEMS MAY BE CONCEALED WITHIN WALL(S) THAT ARE NOT IDENTIFIED ON PLAN.
- PRIOR TO DEMOLITION, REMOVAL OF EXISTING EQUIPMENT AND FURNISHING TO BE COORDINATED WITH OWNER ON WHICH ITEMS TO BE SALVAGED.
- GENERAL CONTRACTOR AND SUB-CONTRACTORS SHALL TAKE CARE TO MINIMIZE THE DAMAGE TO EXISTING FINISHES, SURFACES, AND FURNISHINGS WHICH REMAIN. IF ANY DAMAGE WHICH OCCURS TO ADJACENT SURFACE OR MATERIALS AS A RESULT OF DEMOLITION OR CONSTRUCTION ACTIVITIES SHALL BE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO REPAIR AT THEIR COST.
- GENERAL CONTRACTOR AND SUB-CONTRACTORS TO VERIFY THE EXISTING CONDITIONS AND DETERMINE THE BEST ACTION TO MINIMIZE THE EXTENT OF REMOVAL WORK FOR INSTALLATION OF NEW WORK.
- DO NOT CLOSE OR OBSTRUCT WALKWAYS, EXITS, OR OTHER FACILITIES USED BY OCCUPANTS OF BUILDINGS WITHOUT WRITTEN PERMISSION FROM AUTHORITIES HAVING JURISDICTION.
- INSTALL TEMPORARY DUST PARTITION AND/OR BARRIERS AND OTHER METHODS AS MAY BE REQUIRED/NECESSARY AS INDICATED ON THE PLAN AND AS NECESSARY TO CONTAIN DEMOLITION/CONSTRUCTION DUST AND DEBRIS WITHIN THE AREA OF CONSTRUCTION. REFER TO DUST PARTITION "DP" ON THIS SHEET AND THE SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- IT IS THE INTENT OF THIS DEMOLITION TO REMOVE ALL EXISTING CONSTRUCTION WHICH CONFLICTS WITH THE INTENT OF THE NEW CONSTRUCTION. EVERY DEMOLITION DETAIL MAY NOT NECESSARILY BE COVERED ON THESE DRAWINGS. FIELD VERIFY THE EXTENT OF ALL DEMOLITION.
- THE CONTRACTOR SHALL USE EXTREME CARE IN THE PROTECTION OF ALL ADJACENT AREAS FOR IT IS IMPERATIVE TO PROVIDE CONTINUOUS OPERATION OF ALL OCCUPIED AREAS DURING THE DEMOLITION, CONSTRUCTION AND RENOVATION.
- ALL DEMOLITION DESCRIBED IN THESE DOCUMENTS SHALL BE COORDINATED WITH PHASING WORK REQUIRED TO COMPLETE THE WORK.
- THE CONTRACTOR SHALL COORDINATE ALL DEMOLITION WORK WITHIN OCCUPIED SPACES ABOVE, BELOW AND ADJACENT TO THE WORK. THE CONTRACTOR SHALL NOTIFY THE OWNER AND THE MANAGEMENT OF THE OCCUPIED SPACES ABOVE, BELOW, AND ADJACENT TO THE WORK. TWO WEEKS PRIOR TO COMMENCING WORK, SUCH SPACES ARE TO REMAIN OCCUPIED DURING DEMOLITION AND ALL WORK SHALL BE PERFORMED IN SUCH A MANNER TO MINIMIZE DISRUPTION TO OCCUPIED SPACES. EXISTING FLOOR, WALL AND CEILING FINISHES TO REMAIN SHALL BE PROTECTED AND ANY DAMAGE DONE AS A RESULT OF DEMOLITION WORK SHALL BE REPAIRED.
- IN AREAS SCHEDULED FOR DEMOLITION, THE CONTRACTOR SHALL REMOVE ALL ACCESSORIES: GRAB BARS, MIRRORS, SOAP AND PAPER TOWEL DISPENSERS, SHELVES, BULLETIN BOARDS, ETC., SHALL BE TURNED OVER TO THE OWNER, EXCEPT FOR RELOCATED ITEMS.
- WHERE NEW FINISHES ARE CALLED FOR, REMOVE AND DISCARD EXISTING FLOORING, CEILINGS AND WALL COVERING THROUGHOUT AREA DESIGNATED FOR NEW CONSTRUCTION AND PREP EXISTING FLOOR AND WALL SUBSTRATE TO RECEIVE THE INSTALLATION OF NEW FINISH AS SCHEDULED.
- SEE NEW WORK PLAN FOR REPAIR AND PREPARATION OF ADJACENT SURFACES.
- WHERE CEILING IS TO REMAIN, REMOVE ALL DAMAGED CEILING PANELS/ TILES AND REPLACE WITH NEW TO MATCH EXISTING.
- REMOVE AND RETURN TO THE OWNER ALL EXISTING PLUMBING FIXTURES. CAP ALL SUPPLY AND WASTE LINES AS REQUIRED. REFER TO PLUMBING DRAWINGS FOR ADDITIONAL INFORMATION.
- THE CONTRACTOR SHALL PATCH TO MATCH ADJACENT SURFACES OF EXISTING WALLS, FLOOR, AND CEILINGS IN ALL AREAS THAT REQUIRE THE REMOVAL OF GENERAL MECHANICAL, ELECTRICAL, PLUMBING, AND FIRE PROTECTION WORK AND OF EQUIPMENT AND FIXTURES.
- THE CONTRACTOR SHALL PROVIDE FOR ALL NECESSARY TEMPORARY RELOCATION AND MAINTENANCE OF ALL EXISTING UTILITIES WHICH ARE CURRENTLY IN USE AND WHICH MUST BE TEMPORARILY RELOCATED DURING CONSTRUCTION OF NEW AREAS AND RENOVATION OF EXISTING AREAS.
- REFER TO MECHANICAL, ELECTRICAL, PLUMBING, AND FIRE PROTECTION DRAWINGS FOR WORK REQUIRED FOR NEW CONSTRUCTION.
- WHERE REMOVAL OF EXISTING PARTITIONS, EQUIPMENT, ETC., DISTURBS EXISTING MECHANICAL, PLUMBING OR ELECTRICAL SERVICES, THE CONTRACTOR SHALL MAKE PERMANENT REVISIONS/PROVISIONS AS REQUIRED TO MAINTAIN SERVICES AND IF NECESSARY, PROVIDE TEMPORARY SERVICES TO AREAS NOT SCHEDULED FOR DEMOLITION, RENOVATION, AND/OR NEW CONSTRUCTION.
- WHERE EXISTING WALLS, CEILINGS, OR FLOORS ARE DAMAGED BY THE CONTRACTOR FOR ACCESS TO SERVICES AND NEW CONSTRUCTION WHICH MAY NOT BE INDICATED IN THE CONTRACT DOCUMENTS, THE CONTRACTOR SHALL BE RESPONSIBLE TO PATCH TO MATCH MATERIAL AND FINISHES TO ORIGINAL CONDITIONS. IF EXISTING FINISHES CANNOT BE MATCHED, THE ENTIRE WALL, CEILING, OR FLOOR SHALL BE REFINISHED TO THE NEAREST CORNER OR POSITIVE BREAKING POINT.
- WHEN DEMOLITION CAUSES DAMAGE TO FLOOR SLAB, WALL, OR CEILING SURFACES WHICH WILL REMAIN EXPOSED IN THE FINISHED WORK, SUCH CONDITIONS SHALL BE REPAIRED AND LEVELED AS REQUIRED TO RECEIVE NEW FINISHES.
- WHEN DEMOLITION EXPOSES DAMAGE TO FLOOR SLAB, WALL, OR CEILING SURFACES WHICH WILL REMAIN EXPOSED IN THE FINISHED WORK, SUCH CONDITIONS SHALL BE REPORTED TO THE ARCHITECT AND OWNER WITH A RECOMMENDATION FOR RESOLUTION OF THE CONDITIONS.
- CLEAN AIR GRILLES AND LIGHT FIXTURES THROUGHOUT PROJECT AREA UPON COMPLETION OF WORK.
- EXISTING PARTITION(S) TO REMAIN SHALL BE PATCHED AND REPAIRED AS REQUIRED.
- ALL WALL PROTECTION ACCESSORIES (IE: CORNER GUARDS, CRASH RAILS, ETC.) BEING REMOVED TO BE TURNED OVER TO OWNER UNLESS NOTED OTHERWISE.


C3 EXISTING OPENING JAMB
1 1/2" = 1'-0"



C1 SECTION DETAIL AT OFFICE WINDOW
1 1/2" = 1'-0"



A5 ENLARGED DEMO - OFFICE
1/4" = 1'-0"



A3 OVERALL FIRST FLOOR DEMO - OFFICE PLAN
1/16" = 1'-0"



Samuel K. Beckman - Architect
License - Missouri EA-2011012130

ACI
BOLAND
ARCHITECTS

1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:

MEP CONSULTANT

IMEG Corp.
1600 Baltimore, Suite 300
Kansas City, Missouri 64108
T: 816.842.8437
Licensee's Certificate of Authority Number:
Kansas #E-34

Saint Luke's ED Office Renovation
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

Date 11/12/21
Job Number 3-21024
Drawn By Author
Checked By Checker

| Number | Date | Description |
|--------|----------|---------------|
| 1 | 08/27/21 | ASI #1 |
| 7 | 12/10/21 | ASI #5 Office |

AD2.1.2

© 2021 ACI/BOLAND, Inc.
OFFICE DEMO AND DETAILS

VIEW KEY

NAME

LEVEL NAME

HEIGHT ABOVE PROJECT 0'-0"

1

INDICATES NOTE USED TO DESCRIBE ADDITIONAL INFORMATION ABOUT WORK REQUIRED, SPECIFIC TO THE SHEET AND/OR DETAIL.

INDICATES DIRECTION OF TRUE NORTH

PLAN OR DETAIL NUMBER

PLAN OR DETAIL NAME

1/8" = 1'-0"

PLAN OR DETAIL SCALE

INDICATES SIMILAR DETAIL REFERENCED IN MULTIPLE LOCATIONS

DETAIL REFERRED TO BY SECTION CUT

SHEET DETAIL IS LOCATED ON - T101

LINE TYPE AND TAG KEY:

NEW WORK BY THIS CONTRACTOR (WIDE LINE)

EXISTING TO BE REMOVED (SHORT DASHED PATTERN)

NEW UNDERFLOOR OR UNDERGROUND (LONG DASHED PATTERN)

EXISTING TO REMAIN OR WORK BY OTHERS (NARROW LINE)

EXISTING TO BE REMOVED BY OTHERS (SHORT DASHED PATTERN)

EXISTING UNDERFLOOR OR UNDERGROUND (LONG DASHED PATTERN)

HALFTONING DOES NOT MODIFY SCOPE.

TAG-E TAGS WITH DASH 'E' INDICATES THE REFERENCED OBJECT IS EXISTING

TAG-1 UNDERLINED TAG INDICATES OBJECT IS IN-SCOPE, IF NEW, ADDITIONAL INFORMATION IS AVAILABLE IN A SCHEDULE, MATERIAL LIST, OR SYMBOL LIST

INDICATES AN EXISTING SYSTEM'S POINT OF CONNECTION/REMOVAL

| CONTRACTOR ABBREVIATION KEY | |
|-----------------------------|---------------------------------|
| ABBR: | DESCRIPTION: |
| A.C. | ASBESTOS ABATEMENT CONTRACTOR |
| A.V.C. | AUDIO/VISUAL CONTRACTOR |
| C.C. | CIVIL CONTRACTOR |
| C.M. | CONSTRUCTION MANAGER |
| E.C. | ELECTRICAL CONTRACTOR |
| F.P.C. | FIRE PROTECTION CONTRACTOR |
| F.S.C. | FOOD SERVICE CONTRACTOR |
| G.C. | GENERAL CONTRACTOR |
| H.C. | HEATING CONTRACTOR |
| M.C. | MECHANICAL CONTRACTOR |
| N.C.C. | NURSE CALL CONTRACTOR |
| P.C. | PLUMBING CONTRACTOR |
| S.C. | SECURITY CONTRACTOR |
| T.C. | TECHNOLOGY CONTRACTOR |
| T.C.C. | TEMPERATURE CONTROLS CONTRACTOR |
| V.C. | VENTILATION CONTRACTOR |

| MECHANICAL SYMBOL LIST | |
|----------------------------|--|
| NOT ALL SYMBOLS MAY APPLY. | |
| SYMBOL: | DESCRIPTION: |
| —BD— | BOILER BLOW DOWN |
| —BF— | BOILER FEED WATER |
| —CA— | COMPRESSED AIR |
| —CBR— | CHILLED BEAM RETURN |
| —CBS— | CHILLED BEAM SUPPLY |
| —CR— | CONDENSER WATER RETURN |
| —CS— | CONDENSER WATER SUPPLY |
| —CS15— | CLEAN STEAM - NUMBER INDICATES PRESSURE IN PSIG. |
| —CWR— | CHILLED WATER RETURN |
| —CWS— | CHILLED WATER SUPPLY |
| —DPP— | DRAIN |
| —G— | NATURAL GAS |
| —GV— | GAS REGULATOR VENT |
| —GWR— | GLYCOL WATER RETURN |
| —GWS— | GLYCOL WATER SUPPLY |
| —HCR— | HEATING/CHILLED WATER RETURN |
| —HCS— | HEATING/CHILLED WATER SUPPLY |
| —HC— | REFRIGERANT HOT GAS |
| —HP— | HIGH PRESSURE CONDENSATE |
| —HPS— | HIGH PRESSURE STEAM |
| —HWR— | HEATING WATER RETURN |
| —HWS— | HEATING WATER SUPPLY |
| —LCS— | LOW PRESSURE CLEAN STEAM |
| —LQ— | REFRIGERANT LIQUID |
| —LPC— | LOW PRESSURE CONDENSATE |
| —LPS— | LOW PRESSURE STEAM |
| —LWR— | LOOP WATER RETURN |
| —LWS— | LOOP WATER SUPPLY |
| —MV— | MEDICAL VACUUM |
| —OR— | OIL RETURN |
| —OS— | OIL SUPPLY |
| —PC— | PUMPED CONDENSATE |
| —PD— | PUMPED DISCHARGE |
| —RCR— | RADIANT COOLING RETURN |
| —RCS— | RADIANT COOLING SUPPLY |
| —RWR— | REHEAT WATER RETURN |
| —RWS— | REHEAT WATER SUPPLY |
| —SUC— | REFRIGERANT SUCTION |
| —SV— | SAFETY RELIEF VENT |
| —VAC— | LAB VACUUM |
| — | PIPE CAP |
| — | PIPE DOWN |
| — | PIPE UP OR UP/DOWN |
| — | PITCH PIPE IN DIRECTION |
| — | DIRECTION OF FLOW IN PIPE |
| — | DIELECTRIC CONNECTION |
| — | UNION/FLANGE |
| — | SHUTOFF VALVE NORMALLY OPEN |
| — | SHUTOFF VALVE NORMALLY CLOSED |
| — | THROTTLING VALVE |
| — | BALANCING VALVE (NUMBER INDICATES GPM) |
| — | AUTOMATIC BALANCING VALVE |
| — | MIXING VALVE |
| — | CONTROL VALVE (THREE-WAY) |
| — | CONTROL VALVE (TWO-WAY) |
| — | SOLENOID VALVE |
| — | CHECK VALVE |
| — | BACKFLOW PREVENTER |
| — | SAFETY/RELIEF VALVE |
| — | PRESSURE REDUCING VALVE (LIQUID/GAS) |
| — | PRESSURE REDUCING VALVE (STEAM) |
| — | TRIPLE DUTY VALVE (ANGLE TYPE) |
| — | TRIPLE DUTY VALVE (IN-LINE TYPE) |
| — | PUMP |
| — | VACUUM BREAKER |
| — | "WYE" - STRAINER |
| — | "WYE" - STRAINER W/SHUTOFF VALVE AND HOSE CONNECTION WITH CAP |
| — | BASKET STRAINER |
| — | FLEXIBLE CONNECTION |
| — | PRESSURE/TEMPERATURE TEST PLUG |
| — | REDUCER - REFERENCE SPECIFICATION FOR CONCENTRIC/ECCENTRIC AND FOT/FOB |
| — | SUCTION DIFFUSER WITH SUPPORT FOOT |
| — | AUTOMATIC AIR VENT |
| — | MANUAL AIR VENT |
| — | DRAIN VALVE WITH HOSE CONNECTION AND CAP |
| — | PRESSURE SENSOR (FURNISHED WITH BALL VALVE) |
| — | PRESSURE GAUGE (FURNISHED WITH BALL VALVE) |
| — | DIFFERENTIAL PRESSURE SENSOR |
| — | STATIC SWITCH |
| — | FLOW METER |
| — | FLOW SWITCH |
| — | FLOW SENSOR |
| — | STEAM TRAP (REFER TO SCHEDULE) |
| — | F&T STEAM TRAP (REFER TO SCHEDULE) |
| — | INVERTED BUCKET STEAM TRAP (REFER TO SCHEDULE) |
| — | ALIGNMENT GUIDE |
| — | PIPE ANCHOR |
| — | EXPANSION JOINT |
| — | #.#" IS THE EXPANSION TRAVEL INCHES |
| — | METER |

| MECHANICAL SYMBOL LIST | |
|----------------------------|--|
| NOT ALL SYMBOLS MAY APPLY. | |
| SYMBOL: | DESCRIPTION: |
| — | DIRECTION OF AIR FLOW |
| — | FLEXIBLE DUCT |
| — | MANUAL VOLUME DAMPER |
| —R— | RISE IN DIRECTION OF AIR FLOW |
| —D— | DROP IN DIRECTION OF AIR FLOW |
| — | DUCT CAP |
| — | DUCT DOWN |
| — | DUCT UP |
| — | SUPPLY/OUTSIDE AIR DUCT SECTION |
| — | RETURN AIR DUCT SECTION |
| — | EXHAUST/RELIEF AIR DUCT SECTION |
| — | 4-WAY DIFFUSER WITH BLANKOFF IN ONE DIRECTION |
| SD-1 6/115 | AIR TERMINAL PROPERTIES SYMBOL NECK SIZE/CFM |
| — | TERMINAL AIR BOX (REFER TO SCHEDULE) |
| — | TERMINAL AIR BOX W/REHEAT COIL (REFER TO SCHEDULE) |
| — | FAN POWERED TERMINAL AIR BOX W/REHEAT COIL (REFER TO SCHEDULE) |
| — | HUMIDIFIER |
| — | OPPOSED BLADE DAMPER (REFER TO SCHEDULE) |
| — | PARALLEL BLADE DAMPER (REFER TO SCHEDULE) |
| — | DIFFERENTIAL PRESSURE SENSOR |
| — | HUMIDISTAT SENSOR |
| — | HUMIDISTAT / SENSOR |
| — | CARBON MONOXIDE SENSOR |
| — | CARBON DIOXIDE SENSOR |
| — | OCCUPANCY SENSOR |
| — | PRESSURE SENSOR/MONITOR |
| — | PRESSURE SENSOR (DUCT MOUNTED) |
| — | THERMOSTAT/SENSOR |
| — | TEMPERATURE SENSOR |
| — | THERMOSTAT/SENSOR WITH HEAVY DUTY ENCLOSURE |
| — | TEMPERATURE SENSOR WITH WELL |
| — | THERMOMETER WITH WELL (DIAL TYPE) |
| — | THERMOMETER WITH WELL (FILLED TYPE) |
| —XX-Y | AIRFLOW MEASUREMENT SYMBOL XX - AHU SYMBOL Y - SEQUENTIAL NUMBER |

| MECHANICAL ABBREVIATION KEY | |
|-----------------------------|--------------------------------------|
| ABBR: | DESCRIPTION: |
| AD | ACCESS DOOR |
| AFF | ABOVE FINISHED FLOOR |
| C | COMMON |
| CO | CLEANOUT |
| CFSD | CONTROL/FIRE/SMOKE DAMPER |
| DPG (0-2") | DIFFERENTIAL PRESSURE GAUGE (RANGE) |
| DPS | DIFFERENTIAL PRESSURE SWITCH |
| EA | EXHAUST/RELIEF AIR |
| ECFSD | EXISTING CONTROL FIRE SMOKE DAMPER |
| EFD | EXISTING FIRE DAMPER |
| EFSD | EXISTING FIRE SMOKE DAMPER |
| EP | ELECTRICAL TO PNEUMATIC VALVE |
| ESD | EXISTING SMOKE DAMPER |
| FD | FIRE DAMPER |
| FOB | FLAT ON BOTTOM |
| FOT | FLAT ON TOP |
| FSD | FIRE/SMOKE DAMPER |
| MA | MIXED AIR |
| MV | MIXING VALVE |
| N.C. | NORMALLY CLOSED |
| NC | NOT IN CONTRACT |
| N.O. | NORMALLY OPEN |
| OA | OUTSIDE AIR |
| PS | PRESSURE SWITCH |
| RA | RETURN AIR |
| SA | SUPPLY AIR |
| SCCR | SHORT CIRCUIT CURRENT RATING |
| SD | SMOKE DAMPER |
| TAB | TERMINAL AIR BOX |
| TD | TRANSFER DUCT |
| TYP | TYPICAL |
| UC-1 | DOOR UNDERCUT BY OTHERS (1" TYPICAL) |
| UON | UNLESS OTHERWISE NOTES |

MECHANICAL RENOVATION NOTES:

THESE NOTES APPLY TO ALL MECHANICAL SHEETS AND TRADES, INCLUDING BUT NOT LIMITED TO, FIRE PROTECTION, PLUMBING, MEDICAL GAS, VENTILATION, PIPING AND TEMPERATURE CONTROL.

- EXISTING CONDITIONS ARE SHOWN BASED ON INFORMATION OBTAINED FROM FIELD SURVEYS, EXISTING BUILDING DOCUMENTS, AND STAFF. VERIFY EXISTING CONDITIONS AND REPORT ANY CONFLICTS BEFORE PROCEEDING.
- NOT ALL EXISTING DUCTWORK AND PIPING IS SHOWN. VERIFY EXISTING CONDITIONS BEFORE STARTING WORK. NOTIFY ENGINEER OF ANY CONFLICTS WITH NEW WORK.
- FIELD VERIFY THE AVAILABLE CLEARANCES FOR DUCTWORK AND PIPING BEFORE FABRICATION. RISES AND DROPS MAY BE NECESSARY BECAUSE OF EXISTING FIELD CONDITIONS.
- EACH CONTRACTOR SHALL FIELD VERIFY ACCESSIBILITY TO THE AREA OF HISHER WORK AND SHALL NOTIFY THE **GENERAL CONTRACTOR** PRIOR TO BIDDING IF OTHER UTILITIES ARE REQUIRED TO BE REMOVED OR RELOCATED TO ALLOW ACCESS TO HISHER AREA OF WORK.
- THE GENERAL CONTRACTOR IS RESPONSIBLE FOR CUTTING, REMOVAL AND PATCHING OF ROOFS, WALLS, AND FLOORS ASSOCIATED WITH WORK BY ALL CONTRACTORS. CONTRACTORS SHALL NOTIFY THE GC OF AFFECTED AREAS PRIOR TO BIDDING.
- THE **GENERAL CONTRACTOR** IS RESPONSIBLE FOR REMOVAL AND REPLACEMENT OF CEILINGS, CEILING TILES, AND CEILING GRIDS ASSOCIATED WITH AREAS OF WORK BY ALL CONTRACTORS. NOTIFY THE **GENERAL CONTRACTOR** OF AFFECTED AREAS PRIOR TO BIDDING.
- WHERE EXISTING MECHANICAL SYSTEMS ARE LOCATED IN AREAS THAT CONFLICT WITH NEW EQUIPMENT, PIPING, OR DUCTWORK TO BE INSTALLED, EACH CONTRACTOR SHALL EITHER ARRANGE NEW EQUIPMENT, PIPING, OR DUCTWORK IN SUCH A FASHION THAT IT DOES NOT CONFLICT WITH EXISTING SYSTEMS, OR REWORK EXISTING MECHANICAL SYSTEMS TO ALLOW FOR INSTALLATION OF NEW EQUIPMENT, PIPING, OR DUCTWORK.
- PROVIDE TEMPORARY CONNECTIONS TO MAINTAIN EXISTING SYSTEMS IN SERVICE DURING CONSTRUCTION. MAINTAIN ACCESS TO EXISTING MECHANICAL INSTALLATIONS THAT REMAIN ACTIVE.
- OBTAIN PERMISSION FROM OWNER BEFORE SHUTTING DOWN ANY SYSTEM FOR ANY REASON. MAINTAIN SERVICE TO ALL COMPONENTS THAT ARE TO REMAIN UNTIL NEW SYSTEMS ARE INSTALLED.
- MAINTAIN EXISTING SYSTEM IN SERVICE UNTIL NEW SYSTEM IS COMPLETE AND READY FOR TIE IN AND SWITCHOVER. DRAIN SYSTEM ONLY TO MAKE SWITCHOVERS AND CONNECTIONS. OBTAIN PERMISSION FROM OWNER BEFORE PARTIALLY OR COMPLETELY DRAINING SYSTEM. MAKE CHANGEOVER TO NEW SYSTEMS WITH MINIMUM OUTAGE.

MECHANICAL PHASING NOTES:

THESE NOTES APPLY TO ALL MECHANICAL SHEETS AND TRADES, INCLUDING BUT NOT LIMITED TO, FIRE PROTECTION, PLUMBING, MEDICAL GAS, VENTILATION, PIPING AND TEMPERATURE CONTROL.

- REFER TO DRAWINGS FOR GENERAL DESCRIPTION OF PHASES. REFER TO **GENERAL CONTRACTOR'S** INSTRUCTIONS FOR MORE DETAILS AND PHASING SCHEDULES AND FOR CONCURRENT WORK. MECHANICAL, ELECTRICAL AND TECHNOLOGY DRAWINGS DEPICT THE INTENT OF THE FINAL DESIGN. THE MECHANICAL, ELECTRICAL, AND TECHNOLOGY DRAWINGS DO NOT DEPICT THE MEANS AND METHODS TO MEET THE REQUIREMENTS OF THE PHASING CRITERIA.
- REVIEW PROJECT PHASING PLANS TO COORDINATE DEMOLITION WORK, OUTAGES, ETC. WITH AFFECTED ADJACENT AREAS.
- PROVIDE TEMPORARY DUCTWORK, PIPING, SHUTOFF VALVES, ZONE VALVES, ZONE ALARMS, ETC. AS NEEDED TO MAINTAIN SERVICE TO ALL AREAS DURING ALL PHASES OF PROJECT.
- INSTALL TEMPORARY DUCTWORK, PIPING, SHUTOFF VALVES, ETC. AS NECESSARY TO KEEP ALL OCCUPIED SPACES OPERATIONAL THROUGHOUT ALL PHASES OF THE PROJECT.
- PHASE DEMOLITION WORK TO MINIMIZE DOWNTIME.

TAB PRE-DEMOLITION NOTES:

- BEFORE ANY DEMOLITION WORK IS BEGUN A COMPLETE AIR BALANCE TEST SHALL BE PERFORMED BY THE TESTING, ADJUSTING AND BALANCING (TAB) CONTRACTOR ON EXISTING AIR HANDLERS AND EXHAUST FANS SERVING THE AREAS AFFECTED BY CONSTRUCTION. EQUIPMENT TO BE DEMOLISHED DOES NOT REQUIRE TESTING. PROVIDE AIR BALANCE TESTING ONLY ON EQUIPMENT THAT WILL CONTINUE TO BE USED TO SERVE RENOVATED AREAS AFTER THE CONSTRUCTION PHASE IS COMPLETED.
- PROVIDE DUCT TRAVERSE READINGS AT LOCATIONS DESIGNATED ON THE DRAWINGS BY THE "AIRFLOW MEASUREMENT SYMBOL". THOSE MEASUREMENTS SHALL BE INCLUDED IN THE PRE DEMOLITION REPORT AND SHALL BE DESIGNATED WITH THE IDENTIFIER AS MARKED ON THE DRAWINGS. READINGS SHALL BE DESIGNATED WITH THE ROOM NAME AND NUMBER AS MARKED ON THE DRAWINGS. IF FLOOR PLANS DO NOT HAVE UNIQUE ROOM NAMES AND NUMBERS, TAB CONTRACTOR SHALL INCLUDE FLOOR PLAN WITH UNIQUE NUMBER DESIGNATIONS ASSIGNED TO READINGS THAT MATCH THOSE USED IN THE FINAL PRE-DEMOLITION REPORT. DRAWINGS THAT ARE HAND-MARKED WITH RED INK ARE ACCEPTABLE, PROVIDED THEY ARE LEGIBLE.
- IN THE EVENT A DUCT TRAVERSE LOCATION AS MARKED ON THIS PLAN IS INACCESSIBLE FOR MEASUREMENT, THE TAB CONTRACTOR SHALL PERFORM THE TRAVERSE AT AN ALTERNATE LOCATION OR SHALL TAKE MULTIPLE DUCT TRAVERSES AND/OR READINGS AS REQUIRED TO DETERMINE THE AIRFLOW READING WHERE THE DUCT TRAVERSE SYMBOL IS SHOWN. IN THE EVENT TRAVERSES ARE TAKEN AT ALTERNATE LOCATIONS, TAB CONTRACTOR SHALL INCLUDE A DRAWING THAT SHOWS THE LOCATIONS WHERE THE ACTUAL MEASUREMENTS WERE TAKEN.
- TAKE A DUCT STATIC PRESSURE READING AT EACH LOCATION WHERE A DUCT TRAVERSE READING IS TAKEN AND INCLUDE IN THE FINAL PRE-DEMOLITION TAB REPORT.
- TAB CONTRACTOR SHALL COMPILE AND SUBMIT FOUR COPIES OF THE FINAL PRE-DEMOLITION REPORT WITHIN 10 WORKING DAYS AFTER THE FIELD MEASUREMENTS ARE COMPLETED. FINAL TAB REPORT SHALL BE SUBMITTED FOR REVIEW TO THE ARCHITECT/ENGINEER. TESTING SHALL INCLUDE ALL ITEMS REQUIRED IN THE SPECIFICATIONS.

TAB POST-CONSTRUCTION NOTES:

- AFTER CONSTRUCTION ACTIVITIES ARE COMPLETE, TESTING, ADJUSTING (TAB) AND BALANCING CONTRACTOR SHALL REBALANCE AIR HANDLING UNITS AND EXHAUST FANS AS REQUIRED TO ACHIEVE THE NEW AIRFLOW VALUES SHOWN ON THE CONSTRUCTION DRAWINGS.
- AREAS SERVED BY THIS EQUIPMENT WHICH WERE NOT RENOVATED SHALL BE RE-BALANCED TO THE AIRFLOW RATES MEASURED BEFORE THE RENOVATION OCCURRED (REFER TO THE FINAL PRE-DEMOLITION REPORT).
- IF DUCT TRAVERSE LOCATION AS MARKED ON THE DRAWINGS IS INACCESSIBLE FOR MEASUREMENT, THE TAB CONTRACTOR SHALL PERFORM THE TRAVERSE AT AN ALTERNATE LOCATION OR SHALL TAKE MULTIPLE DUCT TRAVERSES AND/OR GRILLE READINGS AS REQUIRED TO DETERMINE THE FLOW RATE. IN THE EVENT TRAVERSES ARE TAKEN AT AN ALTERNATE LOCATION(S), TAB CONTRACTOR SHALL INCLUDE A DRAWING THAT SHOWS THE LOCATIONS WHERE THE ACTUAL MEASUREMENTS WERE TAKEN.
- A DUCT STATIC PRESSURE READING SHALL BE TAKEN AT EACH LOCATION WHERE A DUCT TRAVERSE READING IS TAKEN AND SHALL BE INCLUDED IN THE FINAL POST-CONSTRUCTION TAB REPORT.
- TAB CONTRACTOR SHALL COMPILE AND SUBMIT COPIES OF THE FINAL POST-CONSTRUCTION TAB REPORT AS REQUIRED BY SECTION 23 05 93.
- THE FINAL POST CONSTRUCTION REPORT SHALL INCLUDE ALL ITEMS REQUIRED IN THE SPECIFICATIONS.

PIPING GENERAL NOTES:

- THE SIZE OF BRANCH PIPING TO TERMINAL HEATING DEVICES AND COILS SHALL BE 3/4" UNLESS NOTED OTHERWISE.
- PIPE DRAIN LINES FROM EQUIPMENT TO NEAREST FLOOR DRAIN.
- INSTALL ALL REFRIGERANT LIQUID AND SUCTION PIPING SIZED PER EQUIPMENT MANUFACTURER RECOMMENDATIONS.

VENTILATION GENERAL NOTES:

- UNLESS NOTED OTHERWISE, THE SIZE OF EACH BRANCH DUCT TO A TERMINAL AIR BOX (TAB) SHALL MATCH THE INLET SIZE UNLESS THE BRANCH IS GREATER THAN 6 FEET IN LENGTH. IN WHICH CASE THE BRANCH DUCT SHALL BE SIZED AT A PRESSURE DROP OF 0.07" W.G. PER 100' OF DUCTWORK.
- UNLESS NOTED OTHERWISE, THE SIZE OF EACH BRANCH DUCT TO AN AIR TERMINAL SHALL MATCH THE INLET SIZE.
- ALIGN TEMPERATURE SENSORS WITH LIGHT SWITCHES AND WHEN IN CLOSE PROXIMITY TO EACH OTHER.
- PROVIDE ACCESS DOORS AT ALL DUCT MOUNTED EQUIPMENT.
- EXISTING AIR INLET AND OUTLET CFM SHOWN ON DRAWINGS ARE FROM EXISTING DRAWINGS, AND ARE FOR REFERENCE ONLY. CONTRACTOR SHALL USE PRE-BALANCE VALVES, AND NOT EXISTING CFM SHOWN ON DRAWINGS.
- CONTRACTOR MAY REUSE PORTIONS OF EXISTING DUCT PROVIDED SIZES AND PRESSURE CLASSES ARE CORRECT, DUCT IS THOROUGHLY CLEANED AND FREE OF DEFECTS, AND ALL TRANSVERSE JOINTS, LONGITUDINAL SEAMS, AND DUCT WALL PENETRATIONS ARE SEALED AS SPECIFIED FOR NEW DUCTWORK.

MECHANICAL GENERAL NOTES:

THESE NOTES APPLY TO ALL MECHANICAL SHEETS AND TRADES, INCLUDING BUT NOT LIMITED TO, FIRE PROTECTION, PLUMBING, MEDICAL GAS, VENTILATION, PIPING AND TEMPERATURE CONTROL.

- DRAWINGS SHOWING LOCATIONS OF EQUIPMENT, DUCTWORK, PIPING, ETC. ARE DIAGRAMMATIC AND MAY NOT ALWAYS REFLECT EXACT INSTALLATION CONDITIONS. DRAWINGS SHOW THE GENERAL ARRANGEMENT OF DUCTWORK, PIPING, EQUIPMENT, ETC., AND MAY NOT INCLUDE ALL OFFSETS AND FITTINGS REQUIRED FOR COMPLETE INSTALLATION. THE DRAWINGS SHALL BE FOLLOWED AS CLOSELY AS ACTUAL BUILDING CONSTRUCTION AND THE WORK OF OTHERS WILL PERMIT.
- DO NOT SCALE DRAWINGS. VERIFY ALL DIMENSIONS AND CLEARANCES FROM ARCHITECTURAL, STRUCTURAL, SUBMITTALS, AND OTHER APPROPRIATE DRAWINGS OR PHYSICALLY AT SITE. REVIEW ALL DRAWINGS, INCLUDING THOSE OF OTHER TRADES.
- COORDINATE ALL WORK WITH ALL OTHER TRADES PRIOR TO INSTALLATION TO PROVIDE CLEARANCES REQUIRED FOR OPERATION, MAINTENANCE, CODE COMPLIANCE, AND TO VERIFY NON-INTERFERENCE WITH OTHER WORK. DO NOT FABRICATE PRIOR TO VERIFICATION OF NECESSARY CLEARANCES FOR ALL TRADES. BRING ANY INTERFERENCES OR CONFLICTS TO THE ATTENTION OF THE ARCHITECT/ENGINEER BEFORE PROCEEDING WITH FABRICATION OR EQUIPMENT ORDERS.
- REVIEW SPACE REQUIREMENTS OF EQUIPMENT SPECIFIED OR SUBSTITUTED AND MAKE REASONABLE ACCOMMODATIONS IN LAYOUT AND POSITIONING TO PROVIDE PROPER ACCESS.
- ANY CHANGES REQUIRED TO ELIMINATE CONFLICTS OR THAT RESULT FROM A FAILURE TO COORDINATE SHALL BE MADE BY THE CONTRACTOR WITHOUT ADDITIONAL COST OR EXPENSE TO OTHERS.
- EACH CONTRACTOR IS RESPONSIBLE FOR ALL COSTS ASSOCIATED WITH ELECTRICAL CHANGES REQUIRED FOR EQUIPMENT PROPOSED THAT DIFFERS FROM THE BASIS OF DESIGN.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLAN, ELECTRICAL, TECHNOLOGY, AUDIO/VISUAL, AND OTHER MECHANICAL PLANS FOR EXACT LOCATIONS OF ALL CEILING MOUNTED DEVICES, OTHER THAN SPRINKLERS.
- EACH CONTRACTOR IS RESPONSIBLE FOR DAMAGE CAUSED BY THEIR ACTIONS TO WALLS, FLOORS, CEILINGS, AND ROOFS. THE CONTRACTOR WHOSE WORK CAUSES DAMAGE IS RESPONSIBLE FOR PATCHING TO MATCH ORIGINAL CONSTRUCTION, FIRE RATING, AND FINISH.
- IN AREAS WITH DRYWALL, CEILINGS COORDINATE LOCATIONS OF ACCESS PANELS WITH THE GC FOR ACCESS TO VALVES, DUCTWORK ACCESSORIES, DAMPERS, ETC. COORDINATE PANEL TYPE AND COLOR WITH ARCHITECT. NOTIFY THE GC OF THE REQUIRED ACCESS PANELS PRIOR TO BIDDING.
- SEAL ALL FLOOR AND WALL PENETRATIONS AIRTIGHT WHERE CONDUITS, PIPING, AND DUCTS PENETRATE.
- CAULK ALL PIPE AND DUCT PENETRATIONS OF FULL HEIGHT NON-FIRE RATED WALL, PARTITION, FLOOR, AND ROOF ASSEMBLIES. THIS IS ESSENTIAL TO PREVENT NOISE TRANSMISSION FROM ONE ROOM TO ANOTHER AND TO PROVIDE THE DESIRED NC LEVELS WITHIN ROOMS.
- WHERE PIPES AND DUCTS ARE SHOWN TO PENETRATE FLOORS, PROVIDE SLEEVED OPENINGS WITH THE TOP EDGE RAISED ABOVE FLOOR SURFACE IN ACCORDANCE WITH ALL RELEVANT SPEC SECTIONS. SEAL SLEEVE PERIMETER TO BE WATERTIGHT.
- EQUIPMENT SIZES AND SERVICE CLEARANCE REQUIREMENTS VARY AMONG DIFFERENT MANUFACTURERS. CONSULT APPROVED SHOP DRAWINGS FOR EQUIPMENT SIZES AND REQUIRED SERVICE CLEARANCES. COORDINATE WITH LAYOUT OF EQUIPMENT PADS, PIPING, DUCTWORK, ETC.
- DO NOT BLOCK TUBE FULL OR EQUIPMENT SERVICE CLEARANCES.
- MAINTAIN MINIMUM 3'-6" CLEARANCE IN FRONT OF ALL ELECTRICAL PANELS, MOTOR STARTERS, SWITCHES, AND DISCONNECTS.
- PROVIDE CONCRETE EQUIPMENT PAD FOR ALL FLOOR MOUNTED EQUIPMENT. PAD SHALL EXTEND MINIMUM 6" BEYOND ALL SIDES OF EQUIPMENT.
- DO NOT SUPPORT EQUIPMENT, PIPING, OR DUCTWORK FROM METAL DECKING OR OTHER NON-STRUCTURAL BUILDING ELEMENTS. ANCHORS EMBEDDED IN CONCRETE SHALL BE CRACKED CONCRETE APPROVED IN ACCORDANCE WITH SPECIFICATIONS.

IMEG

1000 BALTIMORE SUITE 300
KANSAS CITY, MO 64108
816.642.4027
www.imegcorp.com
PROJECT # 21003531.00

Missouri State Certificate of Authority E-201700830
IMEG CORP. RESERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS DRAWING AND THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE THE EXCLUSIVE PROPERTY OF IMEG CORP. AND SHALL NOT BE USED OR REPRODUCED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF IMEG CORP.
© 2021 IMEG CORP.

REFERENCE SCALE IN INCHES

0 1 2 3

RELEASED FOR CONSTRUCTION
Professional Engineer
Bruce E. Hart
Missouri #E-27217

11/12/21

ACI
BOLAND
ARCHITECTS

1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:

MEP CONSULTANT
IMEG
1600 Baltimore, Suite 300
Kansas City, MO 64108
Phone Number: 816-842-8437

Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

Date11/12/21
Job Number3-21024
Drawn ByAuthor
Checked ByChecker


Revision

NumberDateDescription
712-10-21ASI #5


M000.2

© 2021 ACI/BOLAND, Inc.

MECHANICAL COVERSHEET



1 FIRST FLOOR DEMOLITION - PIPING AND CONTROLS - OFFICES
1/4" = 1'-0"



2 FIRST FLOOR - PIPING AND CONTROLS - OFFICES
1/4" = 1'-0"

SHEET NOTES:

1. REFER TO GENERAL NOTES ON SHEET M000.2.
2. PRIOR TO PERFORMING DEMOLITION, TAKE HEATING HOT WATER FLOW READINGS (IN FULL HEATING MODE, AT MAXIMUM FLOW RATE) AT ALL TERMINAL AIR BOX REHEAT COILS WHERE THE CONTROLS ARE BEING UPGRADED UNDER THIS PROJECT AND REPORT RESULTS IN WRITING.
3. TERMINAL AIR BOX (TAB) TAGS ARE BASED ON ROOM NUMBERS SERVED AND MAY NOT MATCH THE BOX TAGS IN THE FACILITY MANAGEMENT AND CONTROL SYSTEM (FMCS).
4. EXISTING FACILITY MANAGEMENT AND CONTROL SYSTEM (FMCS) IS A JOHNSON CONTROLS METASYS SYSTEM. IF A NEW FMCS NETWORK CONTROLLER OR ANY OTHER CENTRALIZED HARDWARE IS REQUIRED TO ALLOW FOR THE CONTROLS UPGRADES, OR IF NEW COMMUNICATIONS WIRING IS REQUIRED, OR IF FMCS SOFTWARE UPDATES ARE REQUIRED, THEN ANY/ALL THOSE SHALL BE INCLUDED IN THE SCOPE OF WORK.
5. EACH DDC UNITARY CONTROLLER SHALL BE POWERED BY EXISTING 24V POWER THAT SERVED THE OLD CONTROLLER. IF NEW 120V OR 24V POWER IS REQUIRED FOR ANY NEW NETWORK HARDWARE OR ANY OTHER REASON, THEN ELECTRICAL PROVISIONS SHALL BE INCLUDED IN THE SCOPE OF WORK.

SPRINKLER NOTE:

SPRINKLER CONTRACTOR SHALL DISCONNECT, RELOCATE AND/OR REMOVE ANY AND/OR ALL SPRINKLER PIPING AND SPRINKLER HEADS AS REQUIRED BY MECHANICAL, ELECTRICAL, AND GENERAL CONTRACTORS. REMOVE ALL SPRINKLER HEADS THAT ARE NOT CONCEALED TYPE. AFTER ALL LARGER DUCTWORK AND PIPING HAVE BEEN INSTALLED, SPRINKLER CONTRACTOR SHALL REINSTALL SPRINKLER HEADS AND/OR PIPING REQUIRED TO SPRINKLER REMODELED SPACE. SPRINKLER CONTRACTOR SHALL ALSO INSTALL NEW HEADS AND/OR PIPING AS REQUIRED BY REMODEL OF SPACE. ALL SPRINKLER HEADS SHALL BE CONCEALED TYPE.

KEYNOTES: (#)

1. DISCONNECT AND REMOVE DDC TERMINAL AIR BOX CONTROLLER, INCLUDING ASSOCIATED 2-WAY HEATING HOT WATER CONTROL VALVE AND MANUAL BALANCING VALVE (NOT SHOWN), AND ANY ASSOCIATED AUXILIARY SENSORS, CONTROL DEVICES, AND/OR CONTROL WIRING THAT CANNOT BE RE-USED. PROTECT TERMINAL AIR BOX AND REMAINING PIPING FOR NEW CONNECTIONS.
2. DISCONNECT AND REMOVE THERMOSTAT ASSOCIATED WITH TERMINAL AIR BOX (OR BOX CONTROLS) BEING REMOVED. REMOVE ANY CONTROL WIRING THAT CANNOT BE RE-USED.
3. PROVIDE AND INSTALL NEW DDC UNITARY CONTROLLER AND NEW PRESSURE-INDEPENDENT CONTROL (PIC) VALVE (NOT SHOWN) ON EXISTING TERMINAL AIR BOX. SIZE THE NEW PIC VALVE FOR REHEAT COIL GPM INDICATED. REFER TO SCHEDULE AND CONTROL DIAGRAM ON SHEET M010.1.

IMEG
1600 BALTIMORE SUITE 300
KANSAS CITY, MO 64108
816.842.8437
www.imegcorp.com
PROJECT # 21003531.00

Missouri State Certificate of Authority E-201700830

IMEG CORP. RESERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS DRAWING AND THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE THE EXCLUSIVE PROPERTY OF IMEG CORP. AND SHALL NOT BE USED OR REPRODUCED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF IMEG CORP.

REFERENCE SCALE IN INCHES
0 1 2 3

RELEASED FOR CONSTRUCTION
Professional Engineer
Bruce E. Hart
Missouri #E-22817
11/12/21

ACI BOLAND ARCHITECTS
1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:


MEP CONSULTANT
IMEG
1600 Baltimore, Suite 300
Kansas City, MO 64108
Phone Number: 816-842-8437

Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086


| | |
|------------|----------|
| Date | 11/12/21 |
| Job Number | 3-21024 |
| Drawn By | Author |
| Checked By | Checker |

| Revision | | |
|----------|----------|-------------|
| Number | Date | Description |
| 7 | 12-10-21 | ASI #5 |

M201.2
© 2021 ACI/BOLAND, Inc.
FIRST FLOOR - MECH PIPING



1 FIRST FLOOR DEMOLITION - VENTILATION - OFFICES
1/4" = 1'-0"



2 FIRST FLOOR - VENTILATION - OFFICES
1/4" = 1'-0"

SHEET NOTES:

1. REFER TO GENERAL NOTES ON SHEET M000.2.
2. PRIOR TO ERECTING CONSTRUCTION BARRIERS OR PERFORMING DEMOLITION, TAKE AIRFLOW READINGS AT BOTH TERMINAL AIR BOXES AND ALL SUPPLY AND RETURN AIR TERMINALS SHOWN ON THIS PLAN AND/OR WITHIN THE PROJECT AREA. REPORT RESULTS IN WRITING.
3. TERMINAL AIR BOX (TAB) TAGS ARE BASED ON ROOM NUMBERS SERVED, AND MAY NOT MATCH THE BOX TAGS IN THE FACILITY MANAGEMENT AND CONTROL SYSTEM (FMCS).

KEYNOTES: **#**

1. LOCK DAMPER IN FULLY OPEN POSITION AND REMOVE ASSOCIATED ACTUATOR. PNEUMATIC TUBING AND/OR WIRING NOT REQUIRED TO REMAIN. INSTALL A SIGN NEAR THE ASSOCIATED DUCT ACCESS DOOR THAT READS, "DAMPER IS NO LONGER REQUIRED AND HAS BEEN DECOMMISSIONED AND LOCKED OPEN."
2. DISCONNECT AND REMOVE DUCTWORK ON DOWNSTREAM SIDE OF TAB, INCLUDING ASSOCIATED AIR TERMINALS. PROTECT TAB FOR NEW CONNECTION. RE: NEW WORK PLAN.
3. COORDINATE EXACT LOCATION OF NEW CONNECTION TO EXISTING 10"x18" RETURN AIR DUCT WITH EXISTING CONDITIONS. CONNECTION MAY NEED TO OCCUR IN CORRIDOR. DO NOT CONNECT TO THE 10"x8" DUCTWORK ABOVE THE OFFICE.
4. ADJUST AIRFLOW SETTINGS FOR EXISTING TAB. ALSO TEST, ADJUST, AND BALANCE ALL AIR TERMINALS ASSOCIATED WITH THIS ZONE (INCLUDING RETURN AIR TERMINALS) TO THE NEW AIRFLOW RATES (CFM) INDICATED.

IMEG
1600 BALTIMORE SUITE 300
KANSAS CITY, MO 64108
816.462.8437
www.imegcorp.com
PROJECT # 21003531.00

Missouri State Certificate of Authority E-201700830

IMEG CORP. RESERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS DRAWING AND THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE THE EXCLUSIVE PROPERTY OF IMEG CORP. AND SHALL NOT BE USED OR REPRODUCED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF IMEG CORP.

REFERENCE SCALE IN INCHES
0 1 2 3

RELEASED FOR CONSTRUCTION
Professional Engineer
Bruce E. Hart
Missouri #E-22817

11/12/21

ACI BOLAND ARCHITECTS
1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:

MEP CONSULTANT
IMEG
1600 Baltimore, Suite 300
Kansas City, MO 64108
Phone Number: 816-842-8437


Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

| Date | 11/12/21 |
|------------|----------|
| Job Number | 3-21024 |
| Drawn By | Author |
| Checked By | Checker |

| Revision | Date | Description |
|----------|----------|-------------|
| 7 | 12-10-21 | ASI #5 |

M211.2
FIRST FLOOR - VENTILATION


12/9/2021 2:32:24 PM



NOTES:

1. TO ATTACH FLEX DUCT TO THE HARD DUCT, TAPE THE INNER LINER TO THE HARD DUCT THEN ATTACH WITH TWO NYLON TIE WRAPS, ONE FOR THE INNER LINER AND ONE FOR THE OUTER SHELL. FOLD THE OUTER SHELL INSIDE ITSELF SO IT HAS NEAT EDGES PRIOR TO TIE WRAPPING.
2. DURABLE ELBOW SUPPORT ACCEPTABLE MANUFACTURER AND MODEL: HART AND COOLEY - SMARTFLOW, THERMAFLEX - FLEXFLOW, TITUS - FLEXRIGHT, OR APPROVED EQUAL.


1 **DIFFUSER CONNECTION DETAIL**
(W/ RADIUS FORMING ELBOW)
NO SCALE



NOTES:

1. THIS DETAIL APPLIES ONLY TO TAPS OFF UNLINED DUCTS.
2. TAP DOES NOT NEED TO BE CONICAL IF THE TAP IS NOT LOCATED BETWEEN FANS AND TERMINAL AIR BOXES. DUCT IS NOT OVER 2" PRESSURE CLASS, AND ROUND DUCT IS NOT OVER 12" DIAMETER.


2 **FLEX DUCT CONNECTION**
(CONICAL/WAPPED)
NO SCALE




NOTES:

1. THIS DETAIL APPLIES ONLY TO TAPS OFF UNLINED DUCTS.
2. TAP DOES NOT NEED TO BE CONICAL IF THE TAP IS NOT LOCATED BETWEEN FANS AND TERMINAL AIR BOXES. DUCT IS NOT OVER 2" PRESSURE CLASS, AND ROUND DUCT IS NOT OVER 12" DIAMETER.
3. MANUFACTURED TAP/DAMPER COMBINATIONS WITH LESS THAN 1/2 DUCT DIAMETER SPACING BETWEEN THE MAIN DUCT AND THE DAMPER SHAFT ARE ACCEPTABLE ONLY IF THE DAMPER SHAFT IS INSTALLED PARALLEL TO THE AIR FLOW IN THE MAIN DUCT.

3 **ROUND DUCT TAP CONNECTION**
(CONICAL/WAPPED)
NO SCALE




4 **HOT WATER COIL PIPING**
NO SCALE



NOTES:

1. THIS DETAIL APPLIES ONLY TO TAPS OFF WRAPPED DUCTS.
2. THIS DETAIL APPLIES TO TERMINAL AIR BOXES WITH ROUND INLETS AND RECTANGULAR OUTLETS.
3. DUCT LEADING TO TAB INLET MUST BE STRAIGHT FOR 1.5 DIAMETER UPSTREAM.
4. MAINTAIN VAPOR BARRIER FROM MAIN TO BRANCH DUCT.

5 **TERMINAL AIR BOX DETAIL**
(WRAPPED MAIN)
NO SCALE



Date 11/12/21
Job Number 3-21024
Drawn By MJL
Checked By DWD

Revision
Number Date Description

M410.2


© 2021 ACI/BOLAND, Inc.
VENTILATION AND PIPING DETAILS

Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

RELEASED FOR CONSTRUCTION
Professional Engineer
Bruce E. Hart
Missouri #E-22817
11/12/21
ACI
BOLAND
ARCHITECTS
1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600
ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:
MEP CONSULTANT
IMEG
1600 Baltimore, Suite 300
Kansas City, MO 64108
Phone Number: 816-842-8437

| CONTROL SYMBOL LIST | | | |
|----------------------------|--|--|---------------------------------------|
| NOT ALL SYMBOLS MAY APPLY. | | | |
| SYMBOL: | DESCRIPTION: | | |
| —CR— | CONDENSER WATER RETURN | | |
| —CS— | CONDENSER WATER SUPPLY | | |
| —CS15— | CLEAN STEAM - NUMBER INDICATES PRESSURE IN PSIG. | | |
| —CWR— | CHILLED WATER RETURN | | |
| —CWS— | CHILLED WATER SUPPLY | | |
| —GWR— | GLYCOL WATER RETURN | | |
| —GWS— | GLYCOL WATER SUPPLY | | |
| —HCR— | HEATING/CHILLED WATER RETURN | | |
| —HCS— | HEATING/CHILLED WATER SUPPLY | | |
| —HPC— | HIGH PRESSURE CONDENSATE | | |
| —HPS— | HIGH PRESSURE STEAM | | |
| —HWR— | HEATING WATER RETURN | | |
| —HWS— | HEATING WATER SUPPLY | | |
| —LPC— | LOW PRESSURE CONDENSATE | | |
| —LPS— | LOW PRESSURE STEAM | | |
| —LWR— | LOOP WATER RETURN | | |
| —LWS— | LOOP WATER SUPPLY | | |
| —PC— | PUMPED CONDENSATE | | |
| —RWR— | REHEAT WATER RETURN | | |
| —RWS— | REHEAT WATER SUPPLY | | |
| —VAC— | LAB VACUUM | | |
| | CONTROL VALVE (THREE-WAY) | | |
| | CONTROL VALVE (TWO-WAY) | | |
| | SOLENOID VALVE | | |
| | CHECK VALVE | | |
| | THERMOSTAT | | |
| | THERMOSTAT/SENSOR WITH HEAVY DUTY ENCLOSURE | | |
| | TEMPERATURE SENSOR (DUCT MOUNTED) | | |
| | TEMPERATURE SENSOR WITH WELL | | |
| | THERMOMETER WITH WELL (DIAL TYPE) | | |
| | THERMOMETER WITH WELL (FILLED TYPE) | | |
| | AVERAGING TEMPERATURE SENSOR | | |
| | LOW LIMIT TEMPERATURE SWITCH | | |
| | PROBE TEMPERATURE SENSOR | | |
| | PRESSURE SENSOR (FURNISHED WITH BALL VALVE) | | |
| | PRESSURE GAUGE (FURNISHED WITH BALL VALVE) | | |
| | DIFFERENTIAL PRESSURE SENSOR | | |
| | PRESSURE SENSOR (DUCT MOUNTED) | | |
| | STATIC SWITCH | | |
| | ANALOG INPUT | | ANALOG OUTPUT |
| | FLOW METER | | HUMIDISTAT SENSOR |
| | FLOW SWITCH | | HUMIDISTAT / SENSOR |
| | FLOW SENSOR | | HUMIDITY SENSOR (DUCT MOUNTED) |
| | AIR FLOW SWITCH | | CARBON MONOXIDE SENSOR |
| | DUCT FLOW METER | | CARBON DIOXIDE SENSOR |
| | HUMIDIFIER | | CARBON MONOXIDE SENSOR (DUCT MOUNTED) |
| | DUCT SMOKE DETECTOR | | CARBON DIOXIDE SENSOR (DUCT MOUNTED) |
| | HEATING/ COOLING COIL | | FILTER |
| | AIR BLENDER | | TERMINAL AIR BOX |
| | MANUAL MOTOR STARTER W/THERMAL OVERLOAD | | TERMINAL AIR BOX W/ REHEAT |
| | FAN | | OCCUPANCY SENSOR |
| | MOTOR | | SENSOR |
| | CONTACTOR | | ACTUATOR |
| | PUMP | | DOOR SWITCH |
| | | | DIFFERENTIAL PRESSURE SWITCH |
| | | | CURRENT SWITCH |
| | | | VIBRATION SWITCH |
| | | | NORMALL CLOSED CONTACT |
| | | | NORMALLY OPEN CONTACT |
| | | | OPPOSED BLADE DAMPER |
| | | | PARALLEL BLADE DAMPER |

| TEMPERATURE CONTROLS ABBREVIATION KEY | |
|---------------------------------------|------------------------|
| ABBR: | DESCRIPTION: |
| EA | EXHAUST/RELIEF AIR |
| MA | MIXED AIR |
| MV | MIXING VALVE |
| N.C. | NORMALLY CLOSED |
| NIC | NOT IN CONTRACT |
| N.O. | NORMALLY OPEN |
| OA | OUTSIDE AIR |
| TYP | TYPICAL |
| RA | RETURN AIR |
| SA | SUPPLY AIR |
| UON | UNLESS OTHERWISE NOTES |



3 TAB CONTROL W/ HOT WATER REHEAT

NO SCALE

EXISTING TERMINAL AIR BOX BALANCING SCHEDULE - OFFICE

| TAG NAME | MIN. INLET SIZE (IN.) DIA. | COOLING MAX. CFM | COOLING MIN. CFM | HEATING MAX. CFM | REHEAT COIL GPM |
|-------------|----------------------------|------------------|------------------|------------------|-----------------|
| B1-1B053A-E | 8" | 400 | 400 | 400 | 1.3 |
| B1-1B053B-E | 7" | 380 | 380 | 380 | 1.3 |
| B1-1B053C-E | 4" | 100 | 50 | 50 | 0.2 |

TERMINAL AIR BOX SCHEDULE - SINGLE DUCT - OFFICE

NOTES:
1. NEITHER RADIATED NOR DISCHARGE SOUND LEVELS SHALL EXCEED NC 35 AT 1.5" INLET STATIC PRESSURE WHEN TESTED PER AHRI STANDARD 885-2008 USING 5/8" 20-LB DENSITY MINERAL FIBER CEILING TILE.
2. TOTAL AIR PRESSURE DROP OF TAB AND REHEAT COIL SHALL NOT EXCEED 0.50" W.C.
3. HEATING COIL IS BASED ON HEATING AIR FLOW. WATER PRESSURE DROP OF REHEAT COILS SHALL NOT EXCEED 5'. PROVIDE REHEAT COILS SEPARATE FROM BOXES IF REQUIRED TO MEET WATER PRESSURE DROP REQUIREMENTS. WHEN LAT °F, EWT °F, AND GPM VALUES ARE BLANK, HEATING COIL IS NOT REQUIRED FOR TAB.
4. HEATING COIL SELECTION SHALL BE BASED ON A FIXED LEAVING AIR TEMPERATURE AND VARIABLE FLOW (GPM). PROVIDE FINAL MAXIMUM FLOW RATE (GPM) TO TEST & BALANCE TEMPERATURE CONTROLS CONTRACTORS.

| TAG NAME | CFM | | HEATING COIL (NOTES 5, 6) | | | | MIN. INLET SIZE (IN.) DIA. | MANUFACTURER | MODEL (NOTES 1, 2) | NOTES |
|-----------|--------------|--------------|---------------------------|--------|--------|--------|----------------------------|--------------|--------------------|------------------|
| | COOLING MAX. | HEATING MAX. | MIN. | EAT °F | LAT °F | EWT °F | MAX. GPM | | | |
| B1-1B053D | 170 | 100 | 100 | 55.0 | 100.0 | 180 | 0.4 | 5" | TITUS | NOTES 1, 2, 3, 4 |
| B1-1B053E | 80 | 50 | 50 | 55.0 | 85.0 | 180 | 0.2 | 4" | TITUS | NOTES 1, 2, 3, 4 |

AIR TERMINAL SCHEDULE - OFFICE

NOTES:
1. CONTRACTOR SHALL DETERMINE PROPER BORDER TYPE TO MATCH CEILING CONSTRUCTION.
2. REFER TO DRAWINGS FOR NECK SIZE. ALL BRANCH DUCTWORK TO AIR TERMINALS SHALL BE NECK SIZE UNLESS NOTED OTHERWISE.

| TAG NAME | FACE SIZE (IN.) (NOTE 2) | TYPE | BORDER (NOTE 1) | MATERIAL | FINISH | VOLUME DAMPER REQUIRED | MANUFACTURER | MODEL | NOTES |
|----------|--------------------------|--|-----------------|----------|--------|------------------------|--------------|-------|------------------|
| RG-1 | 24x12 | LOUVERED FACE GRILLE, 45 DEG. DEFLECTION | LAY-IN | STEEL | WHITE | NO | TITUS | 23RL | OMIT SCREW HOLES |
| SD-1 | 24x24 | | | | | NO | | | |
| SD-1 | 24x24 | SQUARE PLAQUE DIFFUSER | LAY-IN | STEEL | WHITE | NO | TITUS | OMNI | |

1000 BALTIMORE SUITE 300
KANSAS CITY, MO 64108
816.642.8437
www.imegcorp.com
PROJECT # 21003531-00

Missouri State Certificate of Authority E-201700830

IMEG CORP. RESERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS DRAWING AND THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE THE EXCLUSIVE PROPERTY OF IMEG CORP. AND SHALL NOT BE USED OR REPRODUCED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF IMEG CORP.

REFERENCE SCALE IN INCHES
0 1 2 3

RELEASED FOR CONSTRUCTION
RECEIVED BY: [Signature]
DATE: 11/12/21
PROJECT: 21003531-00
BRUCE E. HART
MISSOURI #E-22817

11/12/21

ACI
BOLAND
ARCHITECTS

1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:

MEP CONSULTANT

IMEG
1600 Baltimore, Suite 300
Kansas City, MO 64108
Phone Number: 816-842-8437

Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

Date 11/12/21
Job Number 3-21024
Drawn By MJL
Checked By Checker

Revision
Number 7 Date 12-10-21 Description ASI #5

© 2021 ACI/BOLAND, Inc.

SCHEDULES AND CONTROL DIAGRAMS

| ELECTRICAL SYMBOL LIST | |
|------------------------|---|
| SYMBOL: | DESCRIPTION: |
| | SWITCH - SINGLE POLE |
| | SWITCH - LOCAL TIMER - SPRING WOUND |
| | WATTSTOPPER DIGITAL TIME SWITCH: TS-400 |
| | SWITCH - DOOR JAMB |
| | SWITCH - EMERGENCY |
| | SWITCH - EXPLOSION PROOF |
| | SWITCH - SINGLE POLE - KEY LOCK |
| | SWITCH - LIGHTED HANDLE |
| | SWITCH - MOMENTARY CONTACT |
| | SWITCH - WEATHERPROOF |
| | SWITCH - TWO POLE |
| | SWITCH - TWO POLE - KEY LOCK |
| | SWITCH - THREE WAY |
| | SWITCH - THREE WAY - EMERGENCY |
| | SWITCH - THREE WAY - KEY LOCK |
| | SWITCH - FOUR WAY |
| | SWITCH - FOUR WAY - EMERGENCY |
| | SWITCH - FOUR WAY - KEY LOCK |
| | SWITCH - THREE POSITION-CENTER OFF |
| | COMBINATION SWITCH AND RECEPTACLE |
| | DIMMER - 600 WATT |
| | DIMMER - 600 WATT - 3 WAY |
| | DIMMER - 1000 WATT - 3 WAY |
| | DIMMER - 1500 WATT - 3 WAY |
| | DIMMER - 2000 WATT - 3 WAY |
| | DIMMER - LED - 3-WAY |
| | WATTSTOPPER DUAL TECHNOLOGY DIMMING LINE VOLTAGE WALL OCCUPANCY SENSOR: DSW-311 |
| | WATTSTOPPER DIGITAL LIGHTING MANAGEMENT ROOM CONTROLLER. #- REFERS TO NUMBER OF RELAYS AND D REFERS TO 0-10V DIMMING CONTROLLER |
| | DAYLIGHT LEVEL SENSOR |
| | DAYLIGHT LEVEL SENSOR - 3 ZONE |
| | DAYLIGHT LEVEL SENSOR - 3 ZONE DIMMING |
| | DAYLIGHT LEVEL SENSOR - 3 ZONE DIMMING |
| | WATTSTOPPER DLM SYSTEM PHOTO CELL: LMLS-500 |
| | WATTSTOPPER DUAL TECHNOLOGY CEILING OCCUPANCY SENSOR WITH POWER PACK: LMC0-100 |
| | OCCUPANCY SENSOR - DUAL TECHNOLOGY - WALL MOUNTED |
| | WATTSTOPPER DUAL TECHNOLOGY LINE VOLTAGE WALL OCCUPANCY SENSOR: DSW-301 |
| | SWITCH - OCCUPANCY SENSOR AND DUAL SWITCH - DUAL TECHNOLOGY |
| | OCCUPANCY SENSOR - PASSIVE INFRARED 360 DEGREE COVERAGE |
| | OCCUPANCY SENSOR - PASSIVE INFRARED 100 DEGREE COVERAGE |
| | OCCUPANCY SENSOR - PASSIVE INFRARED - WALL MOUNTED |
| | OCCUPANCY SENSOR - ULTRASONIC 360 DEGREE COVERAGE |
| | OCCUPANCY SENSOR - ULTRASONIC 35X30 HAND MOTION COVERAGE |
| | OCCUPANCY SENSOR - ULTRASONIC TWO SIDED CORRIDOR COVERAGE |
| | OCCUPANCY SENSOR - ULTRASONIC - WALL MOUNTED |
| | WALL CONTROL STATION |
| | TIME SWITCH |
| | WATTSTOPPER DIGITAL LIGHTING MANAGEMENT CONTROL STATION KEYPAD WITH PROGRAMMABLE FUNCTION BUTTONS. # INDICATES NUMBER OF SWITCHES. |
| | ZZ INDICATES TYPE: SX: BUTTON PAD - X: NUMBER OF BUTTONS. D1: ONE BUTTON DIMMING ROCKER SWITCH. |
| | CENTRAL CONTROL - STATION |
| | LIGHTING CONTROL PANEL |
| | LIGHTING CONTROL LCD STATION |
| | NURSE CALL LIGHTING CONTOLLER |
| | AUTOMATIC LOAD CONTROL RELAY - WATT STOPPER EMERGENCY LIGHTING CONTROL UNIT. UPON LOSS OF NORMAL POWER, EMERGENCY LIGHTING SHALL BE BROUGHT TO FULL BRIGHTNESS REGARDLESS OF SWITCH POSITION. PROVIDE ALL LOW VOLTAGE CABLING AS REQUIRED. ELCU-200 |
| | WATTSTOPPER DIGITAL LIGHTING MANAGEMENT INPUT/OUTPUT INTERFACE FOR BMS CONTROL OF LIGHTING. PROVIDE ALL LOW VOLTAGE CABLING AS REQUIRED: IMP-101 |

| ELECTRICAL SYMBOL LIST | |
|------------------------|----------------------------------|
| SYMBOL: | DESCRIPTION: |
| | LINEAR LUMINAIRES |
| | TROFFER |
| | WALL SCONCE LUMINAIRE |
| | DOWNLIGHT LUMINAIRE |
| | AIMABLE OR WALL WASH LUMINAIRE |
| | INDUSTRIAL LUMINAIRE |
| | WALL BRACKET LUMINAIRE |
| | POLE MOUNTED LUMINAIRE |
| | SINGLE FACE EXIT SIGN |
| | DOUBLE FACE EXIT SIGN |
| | WALL/CEILING EMERGENCY EXIT SIGN |
| | EMERGENCY UNIT |

| ELECTRICAL SYMBOL LIST | |
|------------------------|---|
| SYMBOL: | DESCRIPTION: |
| | DUPLEX RECEPTACLE CONTROLLED BY OCCUPANCY |
| | QUAD RECEPTACLE CONTROLLED BY OCCUPANCY |
| | DUPLEX RECEPTACLE, 125V |
| | DUPLEX GFI RECEPTACLE, 125V |
| | GROUND FAULT DEVICE |
| | DUPLEX GFI WEATHERPROOF AND WEATHER RESISTANT LABELED RECEPTACLE 125V |
| | DUPLEX RECEPTACLE, EXPLOSION PROOF, 125V |
| | ISOLATED GROUND RECEPTACLE, 125V |
| | ISOLATED GROUND QUAD RECEPTACLE WITH SURGE SUPPRESSION, 125V |
| | DUPLEX RECEPTACLE, USB CHARGING |
| | ARC FAULT CIRCUIT INTERRUPTER RECEPT 125V |
| | SIMPLEX RECEPTACLE, 125V |
| | RECEPTACLE, 125V |
| | RECEPTACLE 125V, 50A, 125V |
| | RECEPTACLE, 6-20R, 250V |
| | RECEPTACLE, 6-30R, 250V |
| | RECEPTACLE, 6-50R, 250V |
| | RECEPTACLE, 7-20R, 277V |
| | RECEPTACLE, 7-30R, 277V |
| | RECEPTACLE, 7-50R, 277V |
| | RECEPTACLE, 14-20R, 125/250V |
| | RECEPTACLE, 14-30R, 125/250V |
| | RECEPTACLE, 14-50R, 125/250V |
| | RECEPTACLE, 15-20R, 250V, 3PH |
| | RECEPTACLE, 15-30R, 250V, 3PH |
| | RECEPTACLE, 15-50R, 250V, 3PH |
| | RECEPTACLE, 15-60R, 250V, 3PH |
| | RECEPTACLE, LOCKING TYPE, L5-20R, 125V |
| | RECEPTACLE, LOCKING TYPE, L5-30R, 125V |
| | RECEPTACLE, LOCKING L6-20R, 250V |
| | RECEPTACLE, LOCKING L6-30R, 250V |
| | RECEPTACLE, LOCKING L7-20R, 277V |
| | RECEPTACLE, LOCKING L7-30R, 277V |
| | RECEPTACLE, LOCKING L14-20R, 125/250V |
| | RECEPTACLE, LOCKING L14-30R, 125/250V |
| | RECEPTACLE, LOCKING L15-20R, 250V, 3PH |
| | RECEPTACLE, LOCKING L15-30R, 250V, 3PH |
| | RECEPTACLE, L16-20R, 480V, 3PH |
| | RECEPTACLE, L16-30R, 480V, 3PH |
| | RECEPTACLE, LOCKING L21-20R, 120/208V, 3PH |
| | RECEPTACLE, LOCKING L21-30R, 120/208V, 3PH |
| | RECEPTACLE, EXPLOSION PROOF, 125V |
| | DUPLEX RECEPTACLE, TAMPER RESISTANT, 125V |
| | GFI DUPLEX RECEPTACLE, TAMPER RESISTANT, 125V |
| | QUAD RECEPTACLE, 125V |
| | QUAD GFI RECEPTACLE, 125V |
| | QUAD RECEPTACLE, USB 125V |
| | QUAD GFI WEATHER PROOF OR WEATHER RESISTANT LABELED RECEPTACLE, 125V |
| | RECEPTACLE - PEDESTAL STYLE |
| | RECEPTACLE - PEDESTAL STYLE |
| | FLOOR BOX - POKE THRU, 125V |
| | IEC PIN AND SLEEVE RECEPTACLE, 600V |
| | POWER POLE |

| TECHNOLOGY SYMBOL LIST | |
|------------------------|---|
| | AV DEVICE IN FLOOR BOX/POKE THROUGH |
| | N/A AV DEVICE IN FLOOR BOX/POKE THROUGH - EXISTING |
| | AV FLOOR BOX/POKE THROUGH WITH AV |
| | N/A AV FLOOR BOX/POKE THROUGH WITH AV - EXISTING |
| | TECHNOLOGY FLOOR BOX/POKE THROUGH WITH INFORMATION OUTLET |
| | N/A TECHNOLOGY FLOOR BOX/POKE THROUGH WITH INFORMATION OUTLET - EXISTING |
| | N/A TECHNOLOGY FLOOR BOX/POKE THROUGH WITH INFORMATION OUTLET AND AV - EXISTING |
| | INFORMATION OUTLET AND AV DEVICE IN FLOOR BOX/POKE THROUGH |
| | N/A INFORMATION OUTLET AND AV DEVICE IN FLOOR BOX/POKE THROUGH - EXISTING |
| | SC-IO-W INFORMATION OUTLET (WALL) |
| | N/A INFORMATION OUTLET (WALL) EXISTING |
| | INFORMATION OUTLET WALL PHONE (WALL) |
| | N/A INFORMATION OUTLET WALL PHONE (WALL) EXISTING |
| | SC-IO-C INFORMATION OUTLET (CEILING) |
| | N/A INFORMATION OUTLET (CEILING) EXISTING |
| | WAP INFORMATION OUTLET (CEILING) EXISTING |
| | WAP |
| | SC-FF-F |
| | N/A |
| | PA-S1-C |
| | PA-VCL-W |
| | VS-CAM-C |

| ELECTRICAL SYMBOL LIST | |
|------------------------|--|
| SYMBOL: | DESCRIPTION: |
| | GROUND BUS |
| | INTERSYSTEM BONDING TERMINATION |
| | ELECTRICAL CONNECTION |
| | JUNCTION BOX |
| | FLOOR BOX - DUPLEX RECEPTACLE |
| | FLOOR BOX - SEE NOTES BELOW |
| | FLOOR BOX - MULTI SERVICE |
| | TECHNOLOGY ROUGH-IN, FLOOR BOX |
| | FLOOR - SERVICE FITTING |
| | TECHNOLOGY OUTLET ROUGH-IN. REFER TO SPECIFICATION FOR REQUIREMENTS |
| | TECHNOLOGY ROUGH-IN, CEILING |
| | TECHNOLOGY ROUGH-IN, WALL PHONE |
| | TV ANTENNA OUTLET ROUGH-IN |
| | MULTI OUTLET SYSTEM |
| | ELECTRICAL WIREWAY w/ DEVICES SHOWN |
| | ENERGY METER |
| | DIGITAL POWER METER |
| | IMPULSE-TOTALIZING DEMAND |
| | EXTERNAL ENERGY METER |
| | POWER QUALITY METER |
| | CONTROL POWER CABINET |
| | EMERGENCY STOP, N.C. CONTACT |
| | EMERGENCY STOP, N.O. CONTACT |
| | LAMP ANNUNCIATOR |
| | MOMENTARY PUSHBUTTON OPERATOR |
| | PANELBOARD - RECESS MOUNT |
| | PANELBOARD - SURFACE MOUNT |
| | MANUAL SWITCH / STARTER / COMBINATION STARTER/ CIRCUIT BREAKER, REFER TO DISC/STA SCHEDULE |
| | REMOTE ANNUNCIATOR STATION |
| | INTEGRATED POWER CENTER |
| | TRANSFORMER. REFER TO TRANSFORMER SCHEDULE |
| | PACKAGED POWER CENTER |
| | CIRCUIT BREAKER - SURFACE MOUNTED. REFER TO DISC/STA SCHEDULE |
| | CIRCUIT BREAKER - FLUSH MOUNTED. REFER TO DISC/STA SCHEDULE |
| | DISCONNECT. REFER TO DISC/STA SCHEDULE |
| | MOBILE DIAGNOSTICS SERVICE DISCONNECT. REFER TO DISC/STA SCHEDULE |

| NURSE CALL SYMBOL LIST | | |
|------------------------|----------|--|
| | NC-NB-W | NURSE CALL BED INTERFACE (WALL) |
| | NC-NC-W | NURSE CALL CODE BLUE STATION (WALL) |
| | NC-D-W | NURSE CALL DOME LIGHT (WALL) |
| | NC-N2-W | NURSE CALL DUAL PATIENT BED STATION (WALL) |
| | NC-DTY-W | NURSE CALL DUTY STATION (WALL) |
| | NC-NE-W | NURSE CALL EMERGENCY CALL STATION (WALL) |
| | NC-MAS-W | NURSE CALL MASTER STATION (WALL) |
| | NC-NL-W | NURSE CALL PRESENCE LOCATOR (WALL) |
| | NC-NT-W | NURSE CALL PULL CORD STATION - TOILET |
| | NC-N-W | NURSE CALL SINGLE PATIENT BED STATION (WALL) |
| | NC-NA-W | NURSE CALL STAFF ASSIST STATION (WALL) |
| | NC-STF-W | NURSE CALL STAFF STATION (WALL) |
| | NC-DZ-C | NURSE CALL ZONE DOME LIGHT (CEILING) |
| | NC-D-C | NURSE CALL DOME LIGHT (CEILING) |

| SECURITY SYMBOL LIST | | |
|----------------------|------------|---|
| | IA | INTRUSION DETECTION AUDIBLE ALARM (WALL) |
| | ID-DC-W | INTRUSION DETECTION DOOR CONTACT SWITCH (WALL) |
| | ID | INTRUSION DETECTION MOTION DETECTOR (CEILING) |
| | ID | INTRUSION DETECTION MOTION DETECTOR (WALL) |
| | ID | INTRUSION DETECTION SMOKE DETECTOR (CEILING) |
| | ID-VSM-C | INTRUSION DETECTION VAULT ALARM SYSTEM MICROPHONE (CEILING) |
| | ID-VSA-C | ID VAULT ALARM SYSTEM MICROPHONE CONTROLLER (CEILING) |
| | LD | LOCKDOWN DEVICE - ELECTRIC STRIKE |
| | AC-CR1-W | SECURITY CREDENTIAL READER (WALL) TYPE 1 |
| | AC-DR-S | SECURITY DURESS/PANIC BUTTON (SURFACE) |
| | AC-EDR-JUC | SECURITY ELECTRONIC DOOR RELEASE (UNDERCOUNTER) |
| | AC-ST-W | SECURITY STROBE INDICATOR (WALL) |
| | AC-WDR-M | SECURITY WIRELESS DURESS FOB (MOBILE) |
| | ID-GM-C | SECURITY DURESS/PANIC BUTTON (SURFACE) |

| ELECTRICAL SYMBOL LIST | |
|---|--|
| SYMBOL: | DESCRIPTION: |
| COMMON AND SEQUENCE OF OPERATION SUBSCRIPTS | SUBSCRIPTS: TYPE / PROGRAMMING WG = WIRE GUARD IS REQUIRED WP = WEATHERPROOF A = ATRIUM CA = CLEAN AGENT SYSTEM CR = COMPUTER ROOM E = ELEVATOR RECALL D = HVAC CONTROL DH = DOOR HOLD RELEASE DIPS = DUAL INTERLOCK PREACTION SYS FD = FIRE DOOR RELEASE MP = MEDICAL PROCEDURE S = SLEEPING / PATIENT ROOM SW = STAIRWELL # = 15, 30, 75, 110, 177 CANDELA RATING CD = CANDELA RATING SELECTED BY NICET DESIGNER |
| | FIRE ALARM SMOKE DETECTOR, CEILING OR WALL MOUNT |
| | BLANK - PHOTOELECTRIC AT = ATTIC (LOCATED IN) BR = BEAM RECEIVER BT = BEAM TRANSMITTER CO = COMBINATION SMOKE / CARBON MONOXIDE COH = COMBINATION SMOKE / CARBON MONOXIDE / HEAT COS = COMBINATION SMOKE / CARBON MONOXIDE / STROBE H = COMBINATION SMOKE / HEAT DETECTOR ION = IONIZATION TYPE ID = IN DUCT DETECTOR SA = STAND ALONE WITH SOUNDER SB = SOUNDER BASE SV = STAND ALONE WITH SOUNDER FIRE ALARM DUCT SMOKE DETECTOR |
| | # = EQUIP OR SYSTEM |
| | FIRE ALARM AIR SAMPLING SMOKE DETECTION |
| | GAS DETECTION, CEILING OR WALL MOUNT |
| | CO = CARBON MONOXIDE |
| | FIRE ALARM HEAT DETECTOR |
| | BLANK = COMBINATION RATE OF RISE / FIXED TEMP AT = ATTIC (LOCATED IN) F = FIRED TEMP R = RATE COMPENSATED X = EXPLOSION PROOF |
| | HEAT DETECTOR - LINEAR WIRE TYPE |
| | FIRE ALARM FLAME DETECTOR, CEILING OR WALL MOUNT |
| | FIRE ALARM MANUAL PULL STATION |
| | FIRE ALARM MANUAL PULL STATION W/ COVER |
| | FIRE ALARM VISUAL ALARM DEVICE, CEILING OR WALL MOUNT |
| | # = CANDELA RATING CD = CANDELA RATING SELECTED BY NICET DESIGNER |
| | ELECTRIC BELL FOR SPRINKLER SYSTEM |
| | AUDIO HORN/CHIME ALARM DEVICE, CEILING OR WALL MOUNTED |
| | COMBINATION AUDIO HORN/CHIME AND VISUAL ALARM DEVICE, CEILING OR WALL MOUNTED |
| | # = CANDELA RATING CD = CANDELA RATING SELECTED BY NICET DESIGNER |
| | AUDIO (SPEAKER) ALARM DEVICE, CEILING OR WALL MOUNTED |
| | COMBINATION AUDIO (VOICE) AND VISUAL ALARM DEVICE, CEILING OR WALL MOUNTED |
| | # = CANDELA RATING CD = CANDELA RATING SELECTED BY NICET DESIGNER |
| | EMERGENCY VISUAL ALARM DEVICE, CEILING OR WALL MOUNTED |
| | # = CANDELA RATING CD = CANDELA RATING SELECTED BY NICET DESIGNER |
| | EMERGENCY COMBINATION AUDIO (VOICE) AND VISUAL ALARM DEVICE, CEILING OR WALL MOUNTED |
| | # = CANDELA RATING CD = CANDELA RATING SELECTED BY NICET DESIGNER |

| ELECTRICAL ABBREVIATION KEY | |
|-----------------------------|--------------------------|
| ABBR: | DESCRIPTION: |
| AFF | ABOVE FINISHED FLOOR |
| C | CONDUIT |
| GFI | GROUND FAULT INTERRUPTER |
| N.C. | NORMALLY CLOSED |
| NIC | NOT IN CONTRACT |
| N.O. | NORMALLY OPEN |
| SV | SOLENOID VALVE |
| TP | TYPICAL |
| UON | UNLESS OTHERWISE NOTES |

| EMERGENCY SYMBOL KEY | |
|----------------------|---|
| SYMBOL: | DESCRIPTION: |
| | NORMAL BRANCH LUMINAIRE |
| | CRITICAL BRANCH LUMINAIRE |
| | LIFE SAFETY BRANCH LUMINAIRE |
| | CRITICAL BRANCH RECEPTACLE |
| | CRITICAL BRANCH OR LIFE SAFETY BRANCH ELECTRICAL CONNECTION WHERE PANELBOARD IS NOTED CONNECT TO CRITICAL BRANCH. |

ELECTRICAL GENERAL NOTES:

1. (L####) INDICATES THE LIGHTING SEQUENCE OF OPERATION FOR THE SPACE. REFER TO THE LIGHTING SEQUENCE OF OPERATION MATRIX ON SHEET E201.1.
2. ALL CRITICAL BRANCH LUMINAIRES ARE SWITCHED/CONTROLLED DURING NORMAL OPERATION AND OPERATES FROM EMERGENCY CIRCUIT UPON LOSS OF POWER.
3. SHADED LUMINAIRE OR DEVICE INDICATES LUMINAIRE OR DEVICE IS CONNECTED TO AN EMERGENCY CIRCUIT.
4. (B#) PUSH BUTTON REFERS TO SCENE QUANTITY. CONTROL STATION SHALL BE CAPABLE OF RAISE/LOWER AND SWITCHING ON/OFF FOR MULTIPLE SCENES AS INDICATED ON SHEETS AND THE LIGHTING SEQUENCE OF OPERATIONS (L#W). COORDINATE QUANTITIES OF BUTTONS FOR CONTROL STATIONS WITH LIGHTING MANUFACTURER. REFER TO SHEET E-5.1.
5. VACUANCY/OCCUPANCY SENSOR LAYOUT: SENSORS ARE SHOWN ON THE PLANS FOR DESIGN INTENT AND MAY NOT REPRESENT EVERY DEVICE. PROVIDE MANUFACTURER SPECIFIC FLOOR PLAN LAYOUTS SHOWING LOCATION, ORIENTATION, AND COVERAGE AREA OF EACH CONTROL DEVICE, SENSOR, AND CONTROLLER/INTERFACE. AREAS REQUIRING MULTIPLE SENSOR DEVICES FOR APPROPRIATE COVERAGE, SUBMIT SPECIFIC MANUFACTURER-APPROVED SENSOR LAYOUT AS AN OVERLAY DIRECTLY ON THE PROJECT DRAWINGS, EITHER IN PRINT OR APPROVED ELECTRONIC FORM.

LUMINAIRE KEY:

F1 = FIXTURE TAG
1 = CIRCUIT NUMBER
a = SWITCH DESIGNATION
NL = SUBSCRIPT (IF APPLICABLE)
Z = ZONE DESIGNATION

*IF LABEL IS ORIENTED HORIZONTALLY A SLASH WILL SEPARATE THIS INFORMATION. EX: F1 / 1 / a / NL

DEVICE KEY:

A = MOUNTING (IF APPLICABLE)
1 = CIRCUIT NUMBER


*IF LABEL IS ORIENTED HORIZONTALLY A SLASH WILL SEPARATE THIS INFORMATION. EX: A / 1

ELECTRICAL MOUNTING SUBSCRIPT KEY:

A MOUNT AT CENTERLINE ABOVE COUNTER OR BACKSPLASH
C MOUNT AT CEILING
H MOUNT ORIENTED HORIZONTALLY
L MOUNT IN CASEWORK
M MOUNT IN MODULAR FURNITURE
R MOUNT IN SURFACE RACEWAY
EWC ELECTRIC WATER COOLER

ELECTRICAL INSTALLATION NOTES:

1. THE COMPLETE INSTALLATION SHALL BE IN ACCORDANCE WITH THE ADA STANDARDS FOR ACCESSIBLE DESIGN. REFER TO THE ADA GUIDELINES FOR ALL CONFIGURATION DETAILS ON THIS PAGE FOR ADDITIONAL INFORMATION.
2. CIRCUIT NUMBERS ARE SHOWN FOR CIRCUIT IDENTIFICATION. CIRCUITING SHALL AGREE WITH NUMBERING ON THE PANEL. PROVIDED COMMON NEUTRALS MAY NOT BE USED FOR BRANCH CIRCUITS. BALANCE THE LOAD ON PANEL AS EVENLY AS POSSIBLE BETWEEN EACH PHASE.
3. LIFE SAFETY, CRITICAL, EQUIPMENT BRANCH WIRING FOR FEEDERS AND BRANCH CIRCUITS SHALL BE ROUTED IN SEPARATE RACEWAY, JUNCTION BOXES, PULL BOXES, AND CABINETS. WIRING FOR EACH BRANCH SHALL BE INDEPENDENT FROM OTHER BRANCHES, INCLUDING THE NORMAL BRANCH.
4. FLUSH MOUNT ALL LIGHTING CONTROL DEVICES AT +42" FROM FLOOR (CENTERLINE DIMENSION), EXCEPT WHERE OTHERWISE NOTED. DEVICES MAY BE SURFACE MOUNTED WHEN CONDUIT IS SPECIFIED EXPOSED.
5. FLUSH MOUNT ALL DUPLEX RECEPTACLES AND TECHNOLOGY OUTLETS AT +18" FROM FLOOR (CENTERLINE DIMENSION), EXCEPT WHERE OTHERWISE NOTED. RECEPTACLES AND OUTLETS MAY BE SURFACE MOUNTED WHEN CONDUIT IS SPECIFIED EXPOSED.
6. ALL MATERIALS USED TO SEAL PENETRATIONS OF FIRE RATED WALLS AND FLO




LMRC-211
SEQUENCE OF OPERATION: IN
MANUAL-ON/AUTOMATIC OFF.

LMRC-212
SEQUENCE OF OPERATION: IN THIS CONFIGURATION THE LMRC-102 DEFAULTS TO MULTI-LEVEL AUTOMATIC-ON/AUTOMATIC OFF. LOAD (A) TURNS ON AUTOMATICALLY AND LOAD (B) DEFAULTS TO MANUAL-ON CONTROL; BOTH LOADS TURN AUTOMATICALLY OFF.


LMRC-213
IN THIS CONFIGURATION THE LMRC-213 SEQUENCE OF OPERATION: DEFAULTS TO
MULTI-LEVEL AUTOMATIC-ON/AUTOMATIC-OFF OPERATION. LOAD (A) ON THE
LMRC-213 TURNS ON AUTOMATICALLY, WHILE LOAD (B) AND (C) DEFAULTS
ENHANCED ROOM TO MANUAL-ON CONTROL. ALL RELAYS TURN OFF
AUTOMATICALLY.

NOTE:
-FURNISH WITH TWO (2) LMCT-100 DIGITAL WIRELESS CONFIGURATION TOOLS.
-PROVIDE COMMISSIONING AND TRAINING FOR ALL INSTALLATIONS.
-PROVIDE ENGRAVING FOR BUTTONS ON ALL INSTALLATIONS.
-ALL SHIELDING FOR OCCUPANCY SENSORS SHALL BE TURNED OVER TO OWNER.



1 FIRST FLOOR DEMOLITION - LIGHTING - OFFICES

1/4" = 1'-0"



2 FIRST FLOOR - LIGHTING - OFFICES


$$1/4" = 1'-0"$$

SHEET NOTES:

1. REFER TO GENERAL NOTES ON SHEET E000.2

KEYNOTES: (#)

1. EXISTING NORMAL LIGHT FIXTURE TO BE
RELOCATED. LIGHT FIXTURE SHALL REMAIN
CONNECTED TO EXISTING CIRCUIT. PROVIDE
SERVING FIXTURE. REFER TO SHEET NEW
WORK PLAN FOR MORE INFORMATION.
2. CRITICAL BRANCH LIGHT FIXTURE TO REMAIN.
EXISTING LIGHTS IN THIS AREA TO BE
REMOVED SHALL REMAIN FOR RE-USE AS
INDICATED IN NEW LOCATION OF RELOCATED
FIXTURE.
3. NEW LIGHT FIXTURE SHALL BE CONNECTED TO
EXISTING CIRCUIT. PROVIDE SERVING SPARE
10-10/10-LS AND CONTROL WIRING SERVING
EXISTING EMERGENCY FIXTURE IN CORRIDOR
TO BE RELOCATED. NEW LIGHTS TO REMAIN
SHALL BE CONNECTED TO EXISTING CIRCUIT
FROM PANEL 11-18/4N THAT SERVED OLD
LIGHTS. NEW LIGHTS IN THIS AREA TO BE
REMOVED AS INDICATED AT FIXTURE.
4. CRITICAL BRANCH LIGHT FIXTURE IN ROOM
SHALL BE CONNECTED TO EXISTING SPARE
10A. 1PC CIRCUIT BREAKER IN PANEL 11-14/HC.
CIRCUIT TO BE USED IS INDICATED AT FIXTURES.
EXISTING INDICATOR LIGHTS TO REMAIN
EXISTING LOAD, THEN CONNECT CIRCUIT TO
EXISTING BREAKER IN SAME PANEL THAT IS
SPARE.
5. PROGRAM ROOM CONTROLLER AND WALL
SWITCH TO OCCUPANCY SENSING. PROVIDES
LIGHTS ON TO 50% UPON ACTIVATION, TURNS
LIGHTS OFF AFTER 15 MINUTES OF NO
ACTIVITY. WALL SWITCH PROVIDES
MANUAL, DIMMING CONTROL.



Bruce E. Hart
Missouri #E-22817

11/12/21



ACI
BOLAND
ARCHITECTS

1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number

MEP CONSULTANT

IMEG


1600 Baltimore, Suite 300
Kansas City, MO 64108

Phone Number: 816-842-8437

Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

| | |
|------------|----------|
| Date | 11/12/21 |
| Job Number | 3-21024 |
| Drawn By | PLR |
| Checked By | JJJ |


| Revision | | |
|----------|----------|-------------|
| Number | Date | Description |
| 7 | 12-10-21 | ASI #5 |




 **E201.2**

© 2021 ACI/BOLAND, Inc


FIRST FLOOR - LIGHTING - OFFICES




3 SECOND FLOOR - POWER - MECH PENTHOUSE
1/4" = 1'-0"



1 FIRST FLOOR DEMOLITION - POWER - OFFICES
1/4" = 1'-0"



4 FIRST FLOOR - POWER - EMS BREAK
1/4" = 1'-0"



2 FIRST FLOOR - POWER - OFFICES
1/4" = 1'-0"

SHEET NOTES:
1. REFER TO GENERAL NOTES ON SHEET E000.2.

- KEYNOTES:** (#)
- RADIO EQUIPMENT SERVED BY THESE RECEPTACLES AND LOCATED ON THIS WALL AND ASSOCIATED ROOF-MOUNTED ANTENNA SHALL BE RELOCATED BY THE OWNER'S VENDOR. COORDINATE RELOCATION WITH VENDOR.
 - EXISTING EMERGENCY CIRCUITS FROM PANEL B1-15-LC SERVING DEVICES TO BE REMOVED SHALL BE RE-USED TO SERVE NEW EMERGENCY DEVICES.
 - EMERGENCY POWER RECEPTACLES IN THIS ROOM SHALL BE CONNECTED TO EXISTING CIRCUITS FROM B1-15-LC THAT HAVE BEEN MADE SPARE BY DEMOLITION IN AREA. CIRCUITS TO BE RE-USED HAVE BEEN INDICATED AT DEVICES.
 - NEW DEVICE INDICATED SHALL CONNECT TO EXISTING 120V CIRCUIT FROM PANEL B1-15-LN SERVING INDICATED EXISTING DEVICE.
 - NORMAL POWER RECEPTACLES IN THIS ROOM SHALL BE CONNECTED TO EXISTING SPARE 20A, 1P CIRCUIT BREAKER(S) IN PANEL B1-19-LN. CIRCUIT TO WHICH EACH DEVICE SHALL BE CONNECTED HAS BEEN INDICATED. HOWEVER, IF INDICATED CIRCUIT HAS AN EXISTING LOAD, THEN CONNECT CIRCUIT TO A CIRCUIT BREAKER IN SAME PANEL THAT IS SPARE.
 - EMERGENCY RECEPTACLE FOR HAM RADIO EQUIPMENT INSTALLED BY OWNER'S VENDOR. RECEPTACLE SHALL BE MOUNTED WITHIN CABINET HOUSING RADIO EQUIPMENT. COORDINATE EXACT LOCATION WITH VENDOR AND CABINET INSTALLER. RECEPTACLE SHALL BE CONNECTED TO EXISTING SPARE 20A, 1P CIRCUIT BREAKER IN PANEL B1-19-LN AT CIRCUIT POSITION INDICATED.
 - EMERGENCY RECEPTACLE FOR HEAR AND MARGER RADIO EQUIPMENT INSTALLED BY OWNER'S VENDOR. COORDINATE EXACT LOCATION OF SURFACE-MOUNTED DEVICE WITH VENDOR. RECEPTACLE SHALL BE CONNECTED TO EXISTING SPARE 20A, 1P CIRCUIT BREAKER IN PANEL B1-17-LLS AT CIRCUIT POSITION INDICATED.
 - ASSOCIATED RADIO EQUIPMENT TO BE LOCATED IN EQUIPMENT RACK FURNISHED AND INSTALLED BY OWNERS VENDOR. CONTRACTOR SHALL PROVIDE A 4" CONCRETE HOUSEKEEPING PAD FOR RACK. COORDINATE EXACT LOCATION AND SIZE WITH VENDOR.

IMEG 1000 BALTIMORE SUITE 300
KANSAS CITY, MO 64108
816.842.8437
www.imegcorp.com
PROJECT # 21003531.00

Missouri State Certificate of Authority E-201700830

IMEG CORP. RESERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS DRAWING AND THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE THE EXCLUSIVE PROPERTY OF IMEG CORP. AND SHALL NOT BE USED OR REPRODUCED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF IMEG CORP.

REFERENCE SCALE IN INCHES
1 2 3

RELEASED FOR CONSTRUCTION
Professional Engineer
Bruce E. Hart
Missouri #E-22817

13/12/21

ACI BOLAND ARCHITECTS
1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600

ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:


MEP CONSULTANT
IMEG
1600 Baltimore, Suite 300
Kansas City, MO 64108
Phone Number: 816-842-8437

Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086


Date 11/12/21
Job Number 3-21024
Drawn By PLR
Checked By JJJ

Revision
Number Date Description
7 12-10-21 ASI #5


E211.2
FIRST FLOOR - POWER - OFFICES
© 2021 ACI/BOLAND, Inc.




3 SECOND FLOOR - SYSTEMS - MECH PENTHOUSE
1/4" = 1'-0"



1 FIRST FLOOR DEMOLITION - SYSTEMS - OFFICES
1/4" = 1'-0"



4 FIRST FLOOR - SYSTEMS - EMS BREAK
1/4" = 1'-0"



2 FIRST FLOOR - SYSTEMS - OFFICES
1/4" = 1'-0"

SHEET NOTES:
1. REFER TO GENERAL NOTES ON SHEET E000.2.

KEYNOTES: (#)
1. DEVICE TO BE RELOCATED. REFER TO NEW WORK PLAN FOR MORE INFORMATION.
2. NEW LOCATION FOR RELOCATED DEVICE. RE-CONNECT TO EXISTING FIRE ALARM SYSTEM AS REQUIRED.
3. FURNISH AND INSTALL TV OUTLET AND COAX CABLE. CABLE SHALL TERMINATE IN ED IT CLOSET 1034.
4. NEW DATA OUTLETS IN THIS ROOM SHALL BE FURNISHED AND INSTALLED PER SAINT LUKE'S STANDARDS. ASSOCIATED CAT6 CABLING INDICATED SHALL EXTEND TO AND CONNECT TO EXISTING PATCH PANELS IN ED IT CLOSET 1034.
5. DATA OUTLET SHALL BE MOUNTED WITHIN CABINET HOUSING HAM RADIO EQUIPMENT. COORDINATE EXACT LOCATION WITH VENDOR AND CABINET INSTALLER.
6. PROVIDE (1) CAT6 CABLE AND OUTLET FOR HEAR RADIO SYSTEM. CABLE SHALL EXTEND TO THE EXISTING DATA OUTLET AT EXISTING ED DESK STATION WHERE ASSOCIATED RADIO EQUIPMENT IS LOCATED. COORDINATE EXACT LOCATION OF EXISTING OUTLET WITH OWNER AND OWNER'S VENDOR.
7. PROVIDE (2) CAT6 CABLES AND OUTLETS FOR MARCER RADIO SYSTEM. CABLES SHALL EXTEND TO THE EXISTING DATA OUTLETS AT EXISTING ED DESK STATION AND SECONDARY DESK WHERE ASSOCIATED RADIO EQUIPMENT IS LOCATED. COORDINATE EXACT LOCATION OF EXISTING OUTLETS WITH OWNER AND OWNER'S VENDOR.

IMEG
1600 BALTIMORE SUITE 300
KANSAS CITY, MO 64108
816.642.8437
www.imegcorp.com
PROJECT # 21003531.00
Missouri State Certificate of Authority E-201700830
IMEG CORP. RESERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS DRAWING AND THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE THE EXCLUSIVE PROPERTY OF IMEG CORP. AND SHALL NOT BE USED OR REPRODUCED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF IMEG CORP. © 2021 IMEG CORP.
REFERENCE SCALE IN INCHES
0 1 2 3
1/4" = 1'-0"

RELEASED FOR CONSTRUCTION
Professional Engineer
Bruce E. Hart
Missouri #E-22817
11/12/21

ACI BOLAND ARCHITECTS
1710 Wyandotte
Kansas City, MO 64108
T: 816.763.9600
ACI/Boland, Inc.
Kansas City | St. Louis
Licensee's Certificate of Authority Number:
MEP CONSULTANT
IMEG
1600 Baltimore, Suite 300
Kansas City, MO 64108
Phone Number: 816-842-8437

Saint Luke's ED Finish Upgrades
80 NE Saint Luke's Blvd
Lee's Summit, MO 64086

| | |
|------------|----------|
| Date | 11/12/21 |
| Job Number | 3-21024 |
| Drawn By | PLR |
| Checked By | JJJ |

| | | |
|----------|----------|-------------|
| Revision | | |
| Number | Date | Description |
| 7 | 12-10-21 | ASI #5 |

E221.2
© 2021 ACI/BOLAND, Inc.
FIRST FLOOR - SYSTEMS - OFFICES