

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211432
Address: 3105 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, December 16, 2021

Corrective Action Required:

1	Misc	-span rafters properly, glued end joints throughout not correct - (SUBMITTED DOCUMENTATION UNDER REVIEW) -Tempered glass required at great room windows at fireplace and basement den, less than 18" from floor -Install all exterior doors and windows
---	------	---

****OK TO INSULATE****

Comments: