

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20212196  
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Hydrostatic Test</b>	Adam Nacke	Passed	Thursday, December 16, 2021

Informational:  
1 Misc 12-16-21 AN doing pressure test on the water main for park ridge 7th and 8th.  
Test started at 12:45 , 150psi for 2hrs.. ended at 2:45 Test passed

**Comments:**