

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191614  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Friday, December 17, 2021

Informational:	
1	THIRD FLOOR
	-AREAS APPROVED-
	BUILDING C COMPLETE
	BUILDING B COMPLETE
	BUILDING A COMPLETE EXCEPT ELEVATOR

Informational:	
2	SECOND FLOOR
	-AREAS APPROVED-
	BUILDING C: COMPLETE
	BUILDING B: COMPLETE
	BUILDING A: COMPLETE EXCEPT AT ELEVATOR

Informational:

3 FIRST FLOOR

-AREAS APPROVED-

\*\*\*BUILDING C\*\*\*  
COMPLETE

\*\*\*BUILDING B\*\*\*  
COMPLETE

\*\*\*BUILDING A\*\*\*  
COMPLETE

\*\*\*\*MCAL BUILDING\*\*\*  
COMPLETE EXCEPT AS NOTED:

-165- RC OK

-164- COMPLETE RATED LAYER AT DISHWASHER HOOD, RC OK

Corrective Action Required:

4 Miscellaneous  
Correction

-COMPLETE SCREW PATTERN AND SEAL GAPS AND PENETRATIONS AT  
MECHANICAL ROOM 165

Corrective Action Required:

5 ELEVATOR 1

-FUR OUT WALLS OK

-RC AT CEILING OK

-RATED LAYER AT CEILING OK

Comments: