

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191614  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:   | Inspector: | Outcome: | Date:                        |
|---|------------|----------|------------------------------|
| <b>Underground Electrical<br/>Inspection - Commercial</b> | Robb Popp  | Failed   | Friday, December 17,<br>2021 |

Corrective Action Required:

|   |                             |  |
|---|-----------------------------|--|
| 1 | Miscellaneous<br>Correction | -ADDRESS UNDERMINED PIERS AT LIGHT POLES AND EXPOSE OR COMPLETE<br>ALL UNDERGROUND ELECTRICAL FOR INSPECTION<br><br>-CONDUIT FOR (2) LIGHT POLES AT SOUTH ENTRANCE |
|---|-----------------------------|--|

**Comments:**