

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20210775  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector:     | Outcome: | Date:                       |
|--------------------------------------|----------------|----------|-----------------------------|
| <b>Water Line - Hydrostatic Test</b> | Ronald Paynter | Passed   | Saturday, December 18, 2021 |

Informational:  
1 Misc water main held over 150 psi for 2 hours. RP 12-17-21

**Comments:**