

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRPWFC20173611

Address: 3390 NW VILLAGE PARK DR, LEES SUMMIT, MO 640813391 NW VILLAGE PARK DR, LEES SUMMIT,  
MO 64081245 NW KESSLER DR, LEES SUMMIT, MO 64081201 NW KESSLER DR, LEES  
SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Steve Robbins	Passed	Friday, December 17, 2021

Informational:

1	PW-Misc	Casey from Blue Nile chlorinated the water line coming down kessler and we dechlorinated and flushed today. On Monday we will take the first sample. We will now be able to have fire protection for the building of the apartments.Steve Robbins 09/14/2018 4:01 PM
---	---------	--

Corrective Action Required:

2	Miscellaneous Correction	The first round of samples has failed, the contractor flushed and we started over. I took the first second round and the first samples failed. I was already there with the second set of samples and found out they failed so blue Nile just had me have them try anyway. I will find out this afternoon if they passed or failed.Steve Robbins 11/01/2018 8:06 AM
---	-----------------------------	---

Corrective Action Required:

3	Misc	I have not heard anything, Blue Nile was considering if the city's water wasn't passing the test. I told them they were free to test our water and get back with me. The next time we test they will need to chlorinate again and flush before we take more samples. Steve Robbins 11/26/2018 10:52 AM
---	------	--

Informational:

4	Misc	Casey flushed the line on Friday and we took a sample on Monday the 3rd. I did not hear if it passed yet.Steve Robbins 12/04/2018 3:58 PM
---	------	---

Informational:

5	PW-Misc	We had failing samples from blue valley lab. We have switched to Keystone Labs. The public water line on Kessler and Village Park Dr has had 2 passes in a row. Because of different contractors installing the water lines we also had to get a test from the main to the backflow on kessler and on the backflow on Village Park. Dr. We have the passing tests for Kessler but did not take the one for Village Park Dr. Steve Robbins 12/26/2018 10:12 AM
---	---------	---

**Comments:**