

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20215136
Address: 930 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Monday, December 20, 2021

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE BOCA PLATES DWV BREAK ROOM PROVIDE MIDPOINT SUPPORT VERTICALE DWV 2" & SMALLER PROVIDE PLUMBING PROTECTION PLATES BREAK ROOM PROVIDE BONDING SCREW METAL ELECTRICAL BOXES LAND CONDUCTORS IN A BOX ABOBE FRONT COUNTER
---	-----------------------------	--

Comments: