

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210599
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|----------------|----------|-----------------------------|
| Occupancy Inspection - Engineering | Ronald Paynter | Passed | Thursday, December 16, 2021 |

Informational:

1 Misc

Punch list to be completed in 30 days.

1. Small dip in the parking lot that holds water. This has been repaired and is better but still holds water.
2. Overtime fees of \$50.00.

Informational:

2 Misc

Updated Punch List

1. Finish vegetation that was removed for light poles.
2. Make repairs to dip in parking lot where water does not drain and puddles up.
3. Finish installing curb by drive thru.
4. Remove trash bins that are in parking lot.
5. Clean mud and debris off of parking lot.
6. Finish landscaping by curb next to drive thru.

Comments: