

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211584
Address: 2134 NW KILLARNEY LN, LEES SUMMIT, MO 64081
Inspected On: Monday, December 20, 2021
Inspected By: Michael Harkins
Expiration Date: 01/19/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Monday, December 20, 2021

Corrective Action Required:

1	Misc	Pay not ready fees Driveway at 3rd car garage not per plot plan Complete gutters/downspouts at front stoop Sump shall discharge 36" from foundation Land sewer tracer wire in a box at grade
---	------	--